

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
943493-9000	Liquiphant M FTL51H FTL51H-FGW2BC8G5C	1	ST

010	Approval:	F	ATEX II 1/2GD Ex ia IIC T6, WHG/IECEx zone 0/1
020	Process Connection:	GW2	Thread ISO228 G1, 316L, install > Accessory weld-in adapter
030	Probe Length; Type:	BC mm; Ra<1.5um/59uin
040	Electronics; Output:	8	FEL58;SIL NAMUR+test button (H-L signal)
050	Housing; Cable Entry:	G5	F13 IP66/68 / F17 IP66/67 Alu; M20 gland (EEx d > M20 thread)
060	Additional Option:	C	EN10204-3.1 material (316L wetted parts) inspection certificate