

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
943491-9000	Liquiphant M FTL51 FTL51-KCJ2BB4G7A	1	ST

010	Approval:	K	ATEX II 1/2G Ex d IIC T6/IECEEx zone0/1
020	Process Connection:	CJ2	DN50 PN100 B2, 316L flange EN1092-1
030	Probe Length; Type:	BB mm; 316L, Ra<3.2um/126uin
040	Electronics; Output:	4	FEL54;SIL relay DPDT 19-253VAC/19-55VDC
050	Housing; Cable Entry:	G7	T13 IP66/68 Alu, coated; M20 gland, separate conn. compartment (EEx d > M20 thread)
060	Additional Option:	A	Basic version