

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
943490-9000	Liquiphant M FTL50 FTL50-KGQ2AA4G5A	1	ST

010	Approval:	K	ATEX II 1/2G Ex d IIC T6/IECEX zone0/1
020	Process Connection:	GQ2	Thread ISO228 G3/4, 316L, install > Accessory weld-in adapter
030	Probe Length; Type:	AA	Compact; Ra<3.2um/126uin
040	Electronics; Output:	4	FEL54;SIL relay DPDT 19-253VAC/19-55VDC
050	Housing; Cable Entry:	G5	F13 IP66/68 / F17 IP66/67 Alu; M20 gland (EEx d > M20 thread)
060	Additional Option:	A	Basic version