



Ref. Certif. No.

HU-002753

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnector

Name and address of the applicant

Schneider Electric SE
35 rue Joseph Monier
92500, Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS
31 Rue Pierre Mendès,
38050, Grenoble Cedex 09, France

Name and address of the factory

Schneider Electric A.S.
Cizovska 447
39701 Pisek, Czech Republic

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

V3: Ith=63A, Ui=690V, Ue=230...690V;
V4: Ith=80A, Ui=690V, Ue=230...690V
(see Test Report for further ratings)

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Vario - frame V3 and V4;
Types: V3, V4 (to be used with rotary handle: KCF2PZ,
KAF2PZ, KDF2PZ, KBF2PZ),
VBF3, VBF4, VCF3, VCF4, VCCF3,
VCCF4, VVE3, VVE4, VVD3, VVD4;
Add-on modules: VZ3/VZ4: main pole modules,
VZ12: neutral pole module, VZ15: earthing module (PE),
---Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 60947-3:2008 + AMD1:2012 + AMD2:2015
IEC 60947-1:2007 + AMD1:2010 + AMD2:2014
National Differences: CNAs shown in the Test Report Ref. No. which forms part
of this Certificate

28251223 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCent Kft., Division MEEI
H-1132 Budapest, Váci út 48/A/B
www.tuv.com

Date: 2019-10-28

Signature:

