



Certificate of Compliance

Certificate: 70154269

Master Contract: 225619

Project: 80017206

Date Issued: 2019-09-13

Issued To: Telemecanique/Schneider Electric Industries SAS
BP 660
Zone Industrielle No. 3
L'Isle d'Espagnac, 16340
France

The products listed below are eligible to bear the CSA Mark shown

Issued by: *Carlos Frazao*
Carlos Frazao



PRODUCTS

CLASS - C321123 - INDUSTRIAL CONTROL EQUIPMENT Motor Controllers-Auxiliary Devices

Buzzer, open type, illuminated or non-illuminated, Cat. No. XB5KS, may be followed by 2, followed by B, G or M, may be followed by one digit. Suitable for enclosure types 4, 4X, 12 and 13.

Electrical rating:

Type	Voltage	Current
Non-illuminated	24 V ac/dc	28 mA max
Non-illuminated	110-120 V ac/dc	20 mA max
Non-illuminated	230-240 V ac	18 mA max
Illuminated	24 V ac/dc	58 mA max
Illuminated	110-120 V ac/dc	20 mA max
Illuminated	230-240 V ac	35 mA max



Notes:

1. Cat. No. is followed by suffixes designating supply voltage, contacts, markings and colour options.
2. Certified as open type for use in other equipment where the suitability of the combination is determined by CSA.

APPLICABLE REQUIREMENTS

- | | |
|-------------------------------|--|
| CSA C22.2 No. 94.2-15 | - Enclosures for Electrical Equipment, Environmental Considerations |
| CAN/CSA-C22.2 No 60947-1-13 | - Low-Voltage Switchgear and Controlgear - Part 1: General rules |
| CAN/CSA-C22.2 No 60947-5-1-14 | - Low-voltage switchgear and Controlgear - Part 5-1: Control circuit devices and switching elements - Electromechanical control circuit devices. |



Supplement to Certificate of Compliance

Certificate: 70154269

Master Contract: 225619

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80017206	2019-09-13	Update of report to resolve an issue on model XB5KSM following FIR 233806-190806 dated at August 6, 2019. Editorial changes with resistance and capacitor values for the 230VAC model Item 8 of the descriptive report.
000070207504	2019-02-27	Update of report to resolve an issue on model XB5KSB following FIR CSG # 233806181106 dated at Nov6, 2018 (addition of 2 resistors rated 220 ohms for non- illuminated buzzer).
000070154269	2018-01-15	CSA Certification of Buzzer and Illuminated Buzzer, open type, Cat. No. XB5KS (followed by suffixes), panel-mounted, suitable for enclosure type 4, 4X, 12 or 13, according to the applicable requirements of CSA Products Class 3211 23.