

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product
Produit

Uninterruptible power supply

Name and address of the applicant
Nom et adresse du demandeur

APC by Schneider Electric
Boston ONE Campus, 800 Federal Street
Andover MA 01810-1067
UNITED STATES OF AMERICA

Name and address of the manufacturer
Nom et adresse du fabricant

APC by Schneider Electric
Boston ONE Campus, 800 Federal Street
Andover MA 01810-1067
UNITED STATES OF AMERICA
AMERICAN POWER CONVERSION CORPORATION
(A.P.C.) B.V.
2nd Street, PEZA, Cavite Economic Zone
4106 ROSARIO, CAVITE
PHILIPPINES

Name and address of the factory
Nom et adresse de l'usine

Note: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page

Additional Information on page 2

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

200/380, 230/400, 240/415 V, max.54 A, 50/60Hz

Trademark (if any)
Marque de fabrique (si elle existe)



Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeur

TMP

Model / Type Ref.
Ref. De type

DLRT192RMBP2 (External Battery)
FJRT192BP2 (External Battery)
see model matrix

Additional information (if necessary may also be
reported on page 2)
Les informations complémentaires (si nécessaire,
peuvent être indiqués sur la 2^{ème} page)

new model matrix

Additional Information on page 2

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 62040-1(ed.1)

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

206781-AS3-1

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2015-01-22

Signature:

T. Luczak



Ref. Certif. No.

DE1-51155/A4

AMERICAN POWER CONVERSION CORPORATION
(A.P.C.) B.V.
Lot 10, Block 16, Phase IV., 4106 PEZA, ROSARIO,
CAVITE
PHILIPPINES

AMERICAN POWER CONVERSION CORPORATION
(A.P.C.) B.V.
Lot 3, Block 14, Phase III PEZA, 4106 ROSARIO, CAVITE
PHILIPPINES

Additional information (if necessary)
Information complémentaire (si nécessaire)

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2015-01-22

Signature:



T. Luczak

MODEL MATRIX

W W W W W X X Y Y Y Y Y Y Y Y

W W W W W = MANUFACTURERS PREFIX A TO Z (may take up to 5 characters) Low Voltage Isolated Secondary Differences Only(Non-Safety Critical)

X X = VA OUTPUT 0 TO 9 (may take up to 5 characters)
See Current VA Levels below:

8000, 10000

Y Y Y Y Y Y Y Y = UNIT CONFIGURATION A TO Z and/or 0 to 9 (may take up to 10 alphanumeric characters)

Current UPS Configurations : I = International, R or RM = Rack Mount, XL = Extended Run, U = Unit Height, NET = Software in shipping box, PS = Power Switch, B = Black Bezel, BP = Battery Pack, DR = Din Rail Mount

Example of how to use Matrix: SRT 1000 XLI
WWWW XXXXX YYYYYYYY

Product Voltages (all units): 220VAC-240VAC

Product Frequency (all units): 50/60Hz

Maximum Input Current: 54 A

Present Model Prefixes Example: SRT, FJRT, DLRT

Example of Models Covered by Matrix:

SRT10KXLI, SRT10KRMXLI, FJRT10KXLI, SRT8KXLI,
SRT8KRMXLI, FJRT8KXLI, DLRT8KRMXLI

External Battery Pack:

SRT192BP2, SRT192RMBP2, FJRT192BP2, DLRT192RMBP2