



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2005010305148447

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric (China) Co. Ltd. Shanghai Branch
No. 669, Suide Road, Putuo District, Shanghai, China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

NAME AND ADDRESS OF THE FACTORY

A2S Industries (V054244)
Lot 1 Nouvelle Zone Industrielle Sud Ouest de Mohammedia 20800 MOHAMMEDIA MOROCCO

PRODUCT NAME, MODEL AND SPECIFICATION

Trip Wire Switch

XY2CH: 2 pairs:Ui:500V;Uimp:6kV;AC-15:Ue/Ie:AC240V/3A;DC-13:Ue/Ie:DC250V/0.27A;lth:10A;3 pairs:Ui:400V;Uimp:4kV;AC-15:Ue/Ie:AC240V/1.5A;DC-13:Ue/Ie:DC250V/0.1A;lth:6A; IP65; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Aug.25,2020

Valid until: Apr.11,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0372764



产品认证证书

证书编号: CQC2005010305148447

申请人名称及地址

施耐德电气(中国)有限公司上海分公司
上海市普陀区绥德路669号

制造商名称及地址

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Reuil-Malmaison, France

生产企业名称及地址

A2S Industries (V054244)
Lot 1 Nouvelle Zone Industrielle Sud Ouest de Mohammedia 20800 MOHAMMEDIA
MOROCCO

产品名称和系列、规格、型号

拉线开关

XY2CH: 二对触头:Ui:500V;Uimp:6kV;AC-15:Ue/Ie:AC240V/3A;DC-13:Ue/Ie:DC250V/0.27A;lth:10A;
三对触头:Ui:400V;Uimp:4kV;AC-15:Ue/Ie:AC240V/1.5A;DC-13:Ue/Ie:DC250V/0.1A;lth:6A;防护等
级:IP65;型号解释见附件

产品标准和技术要求

GB/T 14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求,特发此证。

发证日期:2020年08月25日 有效期至:2024年04月11日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任:

陆楠



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0372764



产品认证证书

附录

第 1 页 共 2 页

证书编号: CQC2005010305148447

纸号: 372764

型号解释:

XY2CH	1	3	2	5	0	H7	TK
I	II	III	IV	V	VI	VII	VIII

I	产品型号 XY2CH: XY2CH 系列拉线开关
II	型式 1: 急停拉线开关, 带锁扣 3: 一般停止拉线开关, 弹簧返回
III	防护等级 1: 晴软护套, 不带张紧装置 2: 硅树脂护套, 不带张紧装置 3: 晴软护套, 带张紧装置 4: 硅树脂护套, 带张紧装置
IV	复位方式, 弹簧返回按钮 0: 不带复位, 一般停止拉线开关 1: 齐平按钮复位 2: 靴型复位按钮 3: D30 的蘑菇头按钮 4: D30 的钥匙蘑菇头按钮 No. 421 钥匙 5: D30 的钥匙蘑菇头按钮 No. 455 钥匙 6: 拉钮复位 9: D30 的钥匙蘑菇头按钮, 其它型号钥匙解锁
V	触头模块类型 对于一般停止按钮: 1: 1NC+1NO, 瞬动(XE2SP2151) 对急停按钮: 5: 1NC+1NO, 慢断 (XE2NP2151) 7: 2NC, 慢断 (XE2NP2141) 9: 2NC+1NO, 慢断(XE3NP2141)
VI	指示灯 0: 不带指示灯
VII	电缆进线孔 空白: PG13,5 电缆密封管螺纹孔 H7: 1/2 inch NPT 电缆密封管螺纹孔 H29: ISO M20 电缆密封管螺纹孔
VIII	防腐蚀保护 空白: 正常的保护 (红色基座为急停拉线开关, 蓝色基座为一般停止拉线开关) TK: 抗腐蚀处理 (蓝色基座)

注: 此附录与证书同时使用时有效。

主任: 陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



产品认证证书

附录

第 2 页 共 2 页

证书编号: CQC2005010305148447

纸号: 372764

XY2CH	1	3	2	5	0	H7	TK
I	II	III	IV	V	VI	VII	VIII

I	Product type XY2CH: XY2CH series trip wire switch
II	Model 1: Emergency stop, latching 3: Normal stop, spring return
III	Degree of protection 1: Normal bellows, without tension device 2: Silicone bellows, without tension device 3: Normal bellows, with integral tension device 4: Silicone bellows, with integral tension device
IV	Type of reset, by spring return pushbutton 0: Without reset, normal stop 1: Flush 2: Booted 3: Diam. 30 mushroom head 4: Diam. 30 mushroom head operable with key n° 421 5: Diam. 30 mushroom head operable with key n° 455 6: Pull knob 9: Diam. 30 mushroom head operable with key (other number)
V	Type of contact block For normal stop 1: 1NC + 1NO, snap action (XE2SP2151) For emergency stop 5: 1NC + 1NO, slow break (XE2NP2151) 7: 2NC, slow break (XE2NP2141) 9: 2NC + 1NO, slow break (XE3NP2141)
VI	Indicator 0: Without pilot light
VII	Type of cable entry Blank: PG13.5 threaded holes H7: 1/2 inch NPT threaded holes H29: ISO M20 threaded holes
VIII	Protection against corrosion Blank: Normal protection (red housing for emergency stop, blue housing for normal stop) TK: Increased protective treatment against corrosion (blue housing)

注: 此附录与证书同时使用时有效。

主任: 陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>