

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Analog Interfacesr**with type designation(s)
RMPT, RMT, RMC

Issued to

Schneider Electric Asia Pte Ltd
Singapore, Singapore

is found to comply with

Det Norske Veritas' Rules for Classification of Ships, High Speed & Light Craft and Det Norske Veritas' Offshore Standards**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Temperature B**
Humidity B
Vibration A
EMC A
Enclosure *)***) Required protection according to DNVGL Rules shall be provided upon installation on board**Issued at **Hamburg** on **2019-06-26**for **DNV GL**This Certificate is valid until **2024-06-25**.DNV GL local station: **Certification of Materials - Singapore**Approval Engineer: **Marco Rinkel****Joannis Papanuskas**
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

Supply Voltage : 24 V

RMT J/K Converters for J and K type thermocouples
J (Fe-CuNi)
K (Ni-CrNi)

Output Signal: Switchable 0 ...10 V / 0 ... 20 mA; 4 ... 20 mA

RMPT . 0 Converters for Universal Pt100 probes
Output Signal: Switchable 0 ...10 V / 0 ... 20 mA; 4 ... 20 mA

RMPT . 3 Converters for Optimum Pt100 probes
Output Signal: 0 ...10 V or 0 ... 20 mA

RMC Universal Voltage/Current Converters

Output Signal: Switchable 0 ...10 V / 0 ... 20 mA; 4 ... 20 mA
Switchable 0 ... 10 V; +/- 10 V/4 ... 20 mA; 0... 20 mA
0 ...10 V or 0 ... 20 mA or 4 ... 20 mA
Input Signal: 0 ...10 V ; +/- 10 V; 0 ... 50 V; 0 ... 300 V; 0 ... 500 V
4 ... 20 mA; 0... 20 mA ; 0 ... 1.5 A; 0 ... 5 A; 0 ... 15 A

Application/Limitation

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Type Approval documentation

Test report : No. 1392463 dated 17-01-2003; No. E39281 dated 14-02-2003; 56S030312/01 dated 07-05-2003 and 55S021675/CTG/TLH dated 08-10-2002; No. 5903 in compliance with Qualification plan index 1661647 00 K1 05 dated from 13-12-2002 to 16-04-2003

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, November 2016.

Job Id: **262.1-031860-1**
Certificate No: **TAA00002DJ**

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number

Place of Production:

PT Schneider Electric Manufacturing Batam
Batamindo Industrial Park, Jalan Beringin Lot 4 & 208
Muka Kuning, Batam Island, Indonesia

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE