



**Underwriters Laboratories Inc.®**

Northbrook, Illinois • (847) 272-8800

Melville, New York • (516) 271-6200

Santa Clara, California • (408) 985-2400

Research Triangle Park,  
North Carolina • (919) 549-1400

Camas, Washington • (360) 817-5500

## **CERTIFICATE OF COMPLIANCE**

**CERTIFICATE NUMBER:** 121196 - E48340B  
**ISSUE DATE:** November 12, 1996

**Issued to:** Square D Company  
3700 6th Street SW  
Cedar Rapids, IA 52404 USA

**Report Reference:** E48340, July 2, 1986

**This is to Certify that representative samples of:** Molded Case Circuit Breakers and Ground Fault Circuit Interrupters, Type QO and QOB, Series 2


Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 489, Molded Case Circuit Breakers and Circuit Breaker Enclosures.  
UL 943 Ground-Fault Circuit Interrupters.


**Additional Information:**


*The product includes two switched poles and an unswitched pole and is rated 120/240 V, 15-60 A, 60 Hz, Class A. Interrupting Ratings: 10 kA, 120/240 V, 60 Hz. These products are intended to be installed in a Listed panel board or other suitable enclosure, to provide overcurrent protection of conductors and ground fault protection of personnel.*

**Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.**

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" - ; the word "Listed"; a control number (may be alphanumeric) assigned by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

**LOOK FOR THE UL LISTING MARK ON THE PRODUCT**

**Engineer:**   
Underwriters Laboratories Inc.  
Dorothy Trawkowska

**Review Engineer:**   
Underwriters Laboratories Inc.  
Craig Gatto