

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Auxiliary switches
Name and address of the applicant	Schneider Electric Industries SAS 35 Rue Joseph Monier 92500 Rueil-Malmaison France
Name and address of the manufacturer	Schneider Electric Industries SAS 31 Rue Pierre Mendès-France 38320 EYBENS France
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Schneider Electric a.s. Cizovska 447- 397 01 Pisek Czech Republic
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Ui=690 V, Uimp=6 kV, Ith=12 A AC-15: Ue=240 V, Ie=6 A AC-15: Ue=415 V, Ie=4 A AC-15: Ue=500 V, Ie=2 A AC-15: Ue=690 V, Ie=1 A
Trademark (if any)	SCHNEIDER ELECTRIC
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	VZN05, VZN06
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 auxiliary switches to be mounted on VN12, VN20, VCDN12, VCDN20, VCCDN12, VCCDN20, VBDN12, VBDN20 (3-pole switch-disconnectors) This certificate replaces certificate NL-56840 dated on 2019-02-25 due to an address modification.
A sample of the product was tested and found to be in conformity with	IEC 60947-5-1:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	2246301.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands