



Certificate of Compliance

Certificate: 1544371 (LR 32390)

Master Contract: 153555

Project: 2525132

Date Issued: May 15, 2012

Issued to: Schneider Electric USA, Inc.

Square D
3700 6th St SW
Cedar Rapids, IA 52404
USA
Attention: Bill Rezac

The products listed below are eligible to bear the CSA Mark shown



R. Tateishi

Issued by: R. Tateishi, P. Eng.

PRODUCTS

CLASS 4652 06 - SWITCHES - Moulded Case

Molded case switches, Powerpact HD, HG, HJ, HL and HR, 2- and 3-pole, 150A max, 600V ac max, 250V dc max.

Molded case switches, Powerpact JD, JG, JJ, JL and JR, 2- and 3-pole, 250A max, 600V ac max, 250V dc max.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures