

CN52978

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Auxiliary Contact Block

Name and address of the applicant

Schneider Electric Industries SAS 35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS 35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the factory

Note: When more than one factory, please report on page 2

PT. Schneider Electric Manufacturing Batam Jl Beringin Lot4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel. Muka Kuning Kec. Sungai Beduk – Batam, Indonesia

Ratings and principal characteristics

Ui:690V;Ith: 10A;AC-15: Ue/Ie:120V/6A, 690V/1.04A;DC-13: Ue/Ie: 125V/0.55A, 600V/0.1A;IP20

Trademark / Brand (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

LA1KN;

Additional information (if necessary may also be

reported on page 2)

IEC 60947-5-1:2016(4th Edition)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

CB2020CQC-095389

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86-10-83886666 Fax: +86-10-83886282

website: http://www.cqc.com.cn

Mar.09,2021

Signature:

