



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

**CERTIFICATE NO.: 2003010305059254**

## **NAME AND ADDRESS OF THE APPLICANT**

Schneider Electric (China) Co. Ltd. Shanghai Branch  
No. 669, Suide Road, Putuo District, Shanghai, China

## **NAME AND ADDRESS OF THE MANUFACTURER**

Schneider Electric Industries SAS  
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

## **NAME AND ADDRESS OF THE FACTORY**

PT. Schneider Electric Manufacturing Batam  
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning  
Kec. Sungai Beduk – Batam, Indonesia

## **PRODUCT NAME, MODEL AND SPECIFICATION**

Photoelectric Proximity Switch

XUK: Ui: 240V; Supply Voltage : 24~240V AC/DC, 24~240V AC /12~240V DC; AC-12: Ue/Ie: 240V/3A ; DC-12: Ue/Ie: 30V/3A; Sd=1m, 30m ; r0=5m, 7m, 30mf :20Hz; IP65

## **THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T 14048.10-2016

This is to certify that the above mentioned product(s) complies with therequirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

**Valid from: Aug.17,2020Valid until:Aug.17,2025**

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Jul.11,2003

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)  
Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



President:

Lu Mei



## **CHINA QUALITY CERTIFICATION CENTRE**



# 中国国家强制性产品认证证书

证书编号：2003010305059254

## 委托人名称、地址

施耐德电气（中国）有限公司上海分公司  
上海市普陀区绥德路 669 号

## 生产者（制造商）名称、地址

Schneider Electric Industries SAS  
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

## 生产企业名称、地址

PT. Schneider Electric Manufacturing Batam  
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka  
Kuning Kel.Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

## 产品名称和系列、规格、型号

### 光电式接近开关

XUK: Ui: 240V; 供电电压: 24~240V AC/DC, 24~240V AC /12~240V DC; AC-12: Ue/Ie:  
240V/3A ; DC-12: Ue/Ie: 30V/3A; Sd=1m, 30m ; r0=5m, 7m, 30mf:20Hz; 外壳防  
护等级: IP65; 型号解释见附件

## 产品标准和技术要求

GB/T 14048.10-2016

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，  
特发此证。

发证日期：2020 年 08 月 17 日有效期至：2025 年 08 月 17 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2003 年 07 月 11 日

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询  
经中国合格评定国家认可委员会认可 CNAS C001-P



主任：

陆楠



## 中国质量认证中心



# 中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2003010305059254

纸 号: 2626140

型号解释:

XUK	5	A	R	C	N	L2	T
I	II	III	IV	V	VI	VII	VIII

I -	传感器类型 XUK-光电传感器, 方形 50×50×18
II -	系统 0-通用型 5-漫射型 2-对射型 1-反射 9-极化反射
III -	分类 A-塑料
IV -	输出模式 R-AC/DC 继电器输出
V -	触点类型 C-互补型 NO+NC (常开+常闭)
VI -	附加功能 N-无 T-带延时
VII -	连接方式 L2-2米 PVC 电缆 L5-5米 PVC 电缆 L10-10米 PVC 电缆
VIII -	功能(可选项) R-对射型接收器 T-对射型发射器

注: 此附录与证书同时使用时有效。



主 任:

陆梅



## 中国质量认证中心