



## CERTIFICATE OF COMPLIANCE

**CERTIFICATE NUMBER:** 111201-E10027

**ISSUE DATE:**

**December 11, 2001**

**Page 1 of 1**

**Issued to:**

Square D Company  
3700 6th Street S.W.  
Cedar Rapids, IA 52404 USA

**Report Reference:**

**E10027, October 18, 2001**

**This is to Certify that  
representative samples of:**

Molded Case Circuit Breakers, Powerpact R, Catalog number Prefix RG, RJ, RK  
or RL may or may not be preceded by N, F or P.

**Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)  
indicated on this Certificate.**

**Standard(s) for Safety:**

UL 489, Molded Case Circuit Breakers & Circuit Breaker Enclosures


**Additional Information:**

These are two, three or four pole circuit breakers, rated from 600A through 2500A, 600 V ac  
maximum, 50/60 Hz.

Current Interrupting Ratings is as follows:

- 1) 125,000A, 240 V ac, 3 phase, 50/60 Hz
  - 2) 100,000A, 480 V ac, 3 phase, 50/60 Hz
  - 3) 65,000A, 600 V ac, 3 phase, 50/60 Hz
- + also applies to two pole breakers rated 1-3 phase

**Only those products bearing the UL Listing Mark should be considered as being covered by  
UL's Listing and Follow-Up Service.**

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number  
(may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**LOOK FOR THE UL LISTING MARK ON THE PRODUCT**

Engineer: *Lawrence R. Smith*  
Lawrence R. Smith, Lead Eng. Associate  
Underwriters Laboratories Inc.

Review Engineer: *Antonio L. Romanacce*  
Antonio Romanacce, Eng. Team Leader  
Underwriters Laboratories Inc.