



Ref. Certif. No.

HU-002781

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnector

Name and address of the applicant

Schneider Electric SE
35 rue Joseph Monier
92500, Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS
31 Rue Pierre Mendès,
38050, Grenoble Cedex 09, France

Name and address of the factory

Schneider Electric A.S.
Cizovska 447
39701 Pisek, Czech Republic

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

AC 50Hz 3 phase; IP20
U_e: max. 690V; U_i: U_{imp}: 8kV
I_{th}: V02: 12A; V2: 40A
I_{the}: V02: 10A; V2: 32A
I_e: V02: max. 12A; V2: max 40A
I_u: V02: 12A; V2: 40A
(see Test Report for further ratings)
Schneider Electric

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

V0, V01, V1, V02, V2 (switch-disconnectors) - to
be used with rotary handle: KCC1YZ, KCE1YZ,
KCD1PZ, KCF1PZ, KAD1PZ, KAF1PZ, KCC1LZ, KCE1LZ,
KDD1PZ, KDF1PZ, KAC1BZ, KAE1BZ, KBD1PZ, KBF1PZ

(see Test Report for further details)

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-3:2008 + AMD1:2012 + AMD2:2015
IEC 60947-1:2007 + AMD1:2010 + AMD2:2014
National Differences: CNAs shown in the Test Report Ref. No. which forms part
of this Certificate

28251362 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.com

Date: 2019-12-03

Signature:

TÜVRheinland

Kristóf Kertész

Product Certification

Schneider Vario series

V0, V01, V1, V02, V2 (switch-disconnectors)
 VZ01 (add-on main pole for V01)
 VZ02 (add-on main pole for V02)
 VZ11 (add-on neutral pole for V02 and V2)

VZ0 (add-on main pole for V0)
 VZ1 (add-on main pole for V1)
 VZ2 (add-on main pole for V2)
 VZ14 (add-on PE-module for V0; V1; V01; V2; V02)

VCD0	(V0 with red rotary handle and direct mounting)
VCD01	(V01 with red rotary handle and direct mounting)
VCD1	(V1 with red rotary handle and direct mounting)
VCD02	(V02 with red rotary handle and direct mounting)
VCD2	(V2 with red rotary handle and direct mounting)
VCF0	(V0 with red rotary handle and direct mounting)
VCF01	(V01 with red rotary handle and direct mounting)
VCF1	(V1 with red rotary handle and direct mounting)
VCF02	(V02 with red rotary handle and direct mounting)
VCF2	(V2 with red rotary handle and direct mounting)
VCCD0	(V0 with red rotary handle and extended shaft)
VCCD01	(V01 with red rotary handle and extended shaft)
VCCD1	(V1 with red rotary handle and extended shaft)
VCCD02	(V02 with red rotary handle and extended shaft)
VCCD2	(V2 with red rotary handle and extended shaft)
VCCF0	(V0 with red rotary handle and extended shaft)
VCCF01	(V01 with red rotary handle and extended shaft)
VCCF1	(V1 with red rotary handle and extended shaft)
VCCF02	(V02 with red rotary handle and extended shaft)
VCCF2	(V2 with red rotary handle and extended shaft)
VBD0	(V0 with black rotary handle and direct mounting)
VBD01	(V01 with black rotary handle and direct mounting)
VBD1	(V1 with black rotary handle and direct mounting)
VBD02	(V02 with black rotary handle and direct mounting)
VBD2	(V2 with black rotary handle and direct mounting)
VBFO	(V0 with black rotary handle and direct mounting)
VBFO1	(V01 with black rotary handle and direct mounting)
VBFI	(V1 with black rotary handle and direct mounting)
VBFO2	(V02 with black rotary handle and direct mounting)
VBFI2	(V2 with black rotary handle and direct mounting)
VVE0	(V0 with larger red rotary handle and direct mounting)
VVE1	(V1 with larger red rotary handle and direct mounting)
VVE2	(V2 with larger red rotary handle and direct mounting)
VVD0	(V0 with larger black rotary handle and direct mounting)
VVD1	(V1 with larger black rotary handle and direct mounting)
VVD2	(V2 with larger black rotary handle and direct mounting)

Additional information (if necessary)



TÜVRheinland®

Date: 2019-12-03

TÜV Rheinland InterCert Kft., Division MEEI
 H-1132 Budapest, Váci út 48/A-B
 www.tuv.com

Signature:

TÜVRheinland

Krisztof Kertész

