



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2014010305692751

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric (China) Co. Ltd. Shanghai Branch
No. 669, Suide Road, Putuo District, Shanghai, China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

NAME AND ADDRESS OF THE FACTORY

PT. Schneider Electric Manufacturing Batam
JI Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning Kec.
Sungai Beduk – Batam, Indonesia

PRODUCT NAME, MODEL AND SPECIFICATION

Trip wire switch

XY2CJ: 2-pole contact block: Ui:500V; Uimp:6kV; Ith:10A; AC-15:Ue/Ie:240V/3A, DC-13:Ue/Ie:250V/0.27A;
3-pole contact block: Ui:400V; Uimp:4kV; Ith:6A; AC-15:Ue/Ie:240V/1.5A, DC-13:Ue/Ie:250V/0.1A; IP66,IP67;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with therequirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Aug.17,2020**Valid until:**Dec.29,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: May,13,2014

The certificate information is available through CNCA's website: www.cnca.gov.cn
Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

证书编号: 2014010305692751

委托人名称、地址

施耐德电气(中国)有限公司上海分公司
上海市普陀区绥德路669号

生产者(制造商)名称、地址

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

生产企业名称、地址

PT. Schneider Electric Manufacturing Batam
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka
Kuning Kel. Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

产品名称和系列、规格、型号

拉线开关

XY2CJ: 2-pole contact block: Ui:500V; Uimp:6kV; Ith:10A; AC-15:Ue/Ie:240V/3A, DC-13:Ue/Ie:250V/0.27A;
3-pole contact block: Ui:400V; Uimp:4kV; Ith:6A; AC-15:Ue/Ie:240V/1.5A, DC-13:Ue/Ie:250V/0.1A; IP66,IP67; 型号解释见附件

产品标准和技术要求

GB/T 14048.5-2017

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特发此证。

发证日期: 2020年08月17日有效期至: 2023年12月29日
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。
本证书为变更证书, 证书首次颁发日期: 2014年05月13日
本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询
经中国合格评定国家认可委员会认可 CNAS C001-P



主任:

陆楠



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2014010305692751

纸 号: 2626190

型号解释:

<u>XY2CJ</u>	<u>S</u>	<u>1</u>	<u>5</u>	<u>H29</u>
I	II	III	IV	V

I	产品型号 XY2CJ : XY2CJ 系列拉线开关
II	锚点的位置 L : 在左侧 R : 在右侧 S : 直通
III	类型的重置 1 : 按钮 (拉出)
IV	触点块的紧急停止: 5 : 1NC +1NO, 慢动 (XE2NP2151) 6 : 1NC +2NO, 慢动 (XE3NP2151) 7 : 2NC, 慢动 (XE2NP2141) 9 : 2NC +1NO, 慢动 (XE3NP2141)
V	电缆进线孔 空白 : PG13,5 电缆密封管螺纹孔 H7 : 1/2 inch NPT 电缆密封管螺纹孔 H29 : ISO M20 电缆密封管螺纹孔

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

附录

第 2 页 共 2 页

证书编号: 2014010305692751

纸号: 2626190

XY2CJ	S	I	5	H29
I	II	III	IV	V

I	Product type XY2CJ - XY2CJ series trip wire switch
II	Position of the anchor point L : On the left side R : On the right side S : Straight
III	Type of resetting I : Button (by pulling)
IV	Contact block for emergency stop 5 : 1 NC + 1 NO, slow break (XE2NP2151) 6 : 1 NC + 2 NO, slow break (XE3NP2151) 7 : 2 NC, slow break (XE2NP2141) 9 : 2 NC + 1 NO, slow break (XE3NP2141)
V	Type of cable entry Blank: PG 13.5 threaded holes H7 : 1/2 inch NPT threaded holes H29 : ISO M20 threaded holes

注: 此附录与证书同时使用时有效。



主任: 陆楠



中国质量认证中心