



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2004010305109999

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric (China) Co. Ltd. Shanghai Branch
No. 669, Suide Road, Putuo District, Shanghai, China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

NAME AND ADDRESS OF THE FACTORY

SCHNEIDER ELECTRIC INDUSTRIES SA (V054246)
52 Rue De Dion Bouton ZI Nord F-87280 LIMOGES France

PRODUCT NAME, MODEL AND SPECIFICATION

Photoelectric Proximity Switch

XUX: Ui: 250V; input voltage: Ue: 24~240V AC/DC; Relay Output: AC-12:240V/3A ; DC-12:30V/3A;
Sn: 2m, 2.1m, 11m, 14m, 40m; f:20Hz; IP67

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.10-2016

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Aug.26,2020

Valid until: Aug.17,2025

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0379850



产品认证证书

证书编号: CQC2004010305109999

申请人名称及地址

施耐德电气(中国)有限公司上海分公司
上海市普陀区绥德路669号

制造商名称及地址

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

生产企业名称及地址

SCHNEIDER ELECTRIC INDUSTRIES SA(V054246)
52 Rue De Dion Bouton ZI Nord F-87280 LIMOGES France

产品名称和系列、规格、型号

光电式接近开关

XUX: Ui: 250V; 输入电压: Ue: 24~240V AC/DC; 继电器输出: AC-12:240V/3A ; DC-12:30V/3A;
动作距离: 2m, 2.1m, 11m, 14m, 40m; f:20Hz; IP67; 型号解释见附件

产品标准和技术要求

GB/T 14048.10-2016

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020年08月26日 有效期至: 2025年08月17日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0379850



产品认证证书

附录

第 1 页 共 1 页

证书编号: CQC2004010305109999

纸号: 379850

型号解释:

XUX	2	A	R	C	N	T16	R
I	II	III	IV	V	VI	VII	VIII
I -	传感器类型 XUX - 光电传感器, 方形						
II -	系统 0 - 通用型 5 - 漫射型 8 - 带背景抑制的漫射型 2 - 对射型 1 - 反射 9 - 极化反射						
III -	分类 A - 塑料						
IV -	输出模式 R - AC/DC 继电器输出						
V -	触头类型 C - 互补型 NO+NC (常开+常闭)						
VI -	附加功能 N - 无 T - 带延时						
VII -	连接 T16 - 螺钉端子, ISO16 电缆密封管 M12 - M12 连接器						
VIII -	功能(可选项) R - 对射型接收器 T - 对射型发射器						

注: 此附录与证书同时使用时有效。

主任: 陆楠



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>