



# PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2014010305692751

## NAME AND ADDRESS OF THE APPLICANT

Schneider Electric (China) Co. Ltd. Shanghai Branch  
No. 669, Suide Road, Putuo District, Shanghai, China

## NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industries SAS  
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

## NAME AND ADDRESS OF THE FACTORY

PT. Schneider Electric Manufacturing Batam (V049531)  
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning Kec. Sungai  
Beduk – Batam, Indonesia

## PRODUCT NAME, MODEL AND SPECIFICATION

Trip wire switch

XY2CJ: 2-pole contact block: Ui:500V; Uimp:6kV; Ith:10A; AC-15:Ue/Ie:240V/3A, DC-13:Ue/Ie:250V/0.27A;  
3-pole contact block: Ui:400V; Uimp:4kV; Ith:6A; AC-15:Ue/Ie:240V/1.5A, DC-13:Ue/Ie:250V/0.1A; IP66,IP67;

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

## TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Aug.25,2020

Valid until: Dec.29,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President: \_\_\_\_\_

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0372615



# 产品认证证书

证书编号: CQC2014010305692751

申请人名称及地址

施耐德电气(中国)有限公司上海分公司  
上海市普陀区绥德路669号

制造商名称及地址

Schneider Electric Industries SAS  
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

生产企业名称及地址

PT. Schneider Electric Manufacturing Batam(V049531)  
JI Beringin Lot 4, Lot 208, Lot 1, Lot.15, Lot 16, DAN Lot 16A BIP Muka  
Kuning Kel.Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

产品名称和系列、规格、型号

拉线开关

XY2CJ: 2-pole contact block: Ui:500V; Uimp:6kV; Ith:10A; AC-15:Ue/Ie:240V/3A, DC-13:Ue/Ie:250V/0.27A;  
3-pole contact block: Ui:400V; Uimp:4kV; Ith:6A; AC-15:Ue/Ie:240V/1.5A, DC-13:Ue/Ie:250V/0.1A; IP66,IP67; 型  
号解释见附件

产品标准和技术要求

GB/T 14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。  
发证日期: 2020年08月25日 有效期至: 2023年12月29日  
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任: \_\_\_\_\_

陆楠



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C. 0372615



# 产品认证证书

附录

第 1 页 共 2 页

证书编号: CQC2014010305692751

纸号: 372615

型号解释:

XY2CJ	S	1	5	H29
I	II	III	IV	V

I	产品型号 XY2CJ : XY2CJ 系列拉线开关
II	锚点的位置 L : 在左侧 R : 在右侧 S : 直通
III	类型的重置 1 : 按钮 (拉出)
IV	触点块的紧急停止: 5 : INC +1NO, 慢动 (XE2NP2151) 6 : INC +2NO, 慢动 (XE3NP2151) 7 : 2NC, 慢动 (XE2NP2141) 9 : 2NC +1NO, 慢动 (XE3NP2141)
V	电缆进线孔 空白 : PG13,5 电缆密封管螺纹孔 H7 : 1/2 inch NPT 电缆密封管螺纹孔 H29 : ISO M20 电缆密封管螺纹孔

注: 此附录与证书同时使用时有效。

主任: 陆楠



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



# 产品认证证书

附录

第 2 页 共 2 页

证书编号: CQC2014010305692751

纸号: 372615

XY2CJ	S	I	5	H29
I	II	III	IV	V

I	Product type XY2CJ - XY2CJ series trip wire switch
II	Position of the anchor point L : On the left side R : On the right side S : Straight
III	Type of resetting I : Button (by pulling)
IV	Contact block for emergency stop 5 : 1 NC + 1 NO, slow break (XE2NP2151) 6 : 1 NC + 2 NO, slow break (XE3NP2151) 7 : 2 NC, slow break (XE2NP2141) 9 : 2 NC + 1 NO, slow break (XE3NP2141)
V	Type of cable entry Blank: PG 13.5 threaded holes H7 : 1/2 inch NPT threaded holes H29 : ISO M20 threaded holes

注: 此附录与证书同时使用时有效。

主任: 陆杨



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>