

Certificate of Compliance

Certificate Number 210306A-E84967
Report Reference E84967, March 28, 1991
Issue Date 2006 March 21

Page 1 of 1



Issued to: **SQUARE D CO.**
3700 6TH ST SW
CEDAR RAPIDS, IA 52404


This is to certify that representative samples of **Molded Case Circuit Breakers**
Types QOT Series 2

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 489, Molded Case Circuit Breakers and Circuit Breaker Enclosures

Additional Information: These are two and four pole circuit breakers, rated from 15 A through 30 A. Current Interrupting Rating is as follows: 10,000 A, 120/240 V ac, 1 phase, 50/60 Hz.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Hilary Frei*
Hilary Frei
Underwriters Laboratories Inc.

Reviewed by: *Jeffrey Hidaka*
Jeffrey Hidaka
Underwriters Laboratories Inc.