



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2010010304430984

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric (China) Co. Ltd. Shanghai Branch
No. 669, Suid Road, Putuo District, Shanghai, China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

NAME AND ADDRESS OF THE FACTORY

PT. Schneider Electric Manufacturing Batam (V049531)
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning Kec. Sungai
Beduk – Batam, Indonesia

PRODUCT NAME, MODEL AND SPECIFICATION

Contact block

XESP1021, XESP1031, XESP2021, XESP20215, XESP2031, XESP20315,
XESP3021;Ui:500V;Uimp:4kV;lth:10A;AC-15:Ue/Ie:240V/3A;DC-13:Ue/Ie:250V/0.27A;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification
rules of CQC11-462142-2019 .

Valid from: Aug.26,2020

Valid until: Nov.20,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing
certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-R

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0379854



产品认证证书

证书编号: CQC2010010304430984

申请人名称及地址

施耐德电气(中国)有限公司上海分公司
上海市普陀区绥德路669号

制造商名称及地址

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

生产企业名称及地址

PT. Schneider Electric Manufacturing Batam(V049531)
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka
Kuning Kel.Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

产品名称和系列、规格、型号

触头模块

XESP1021, XESP1031, XESP2021, XESP20215, XESP2031, XESP20315,
XESP3021;Ui:500V;Uimp:4kV;lth:10A;AC-15:Ue/le:240V/3A;DC-13:Ue/le:250V/0.27A;型号解释见附件

产品标准和技术要求

GB/T 14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020年08月26日 有效期至: 2024年11月20日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任: _____

陆杨



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0379854



产品认证证书

附录

第 1 页 共 1 页

证书编号: CQC2010010304430984

纸号: 379854

型号解释:

<u>XESP</u>	<u>2</u>	<u>0</u>	<u>2</u>	<u>1</u>	<u>5</u>
I	II	III	IV	V	VI
I	XESP 瞬动触头模块基本型号				
II	1.有周边围栏, 动触头的厚度为 0.75mm. 2.有周边围栏 3 无固定孔, 用于 XCK5 限位开关				
III	0.无接线端子保护				
IV	2.2C/O 同时瞬动 3.2 C/O 交叉式瞬动				
V	1.银合金触头				
VI	空白: 正常产品 5.特殊产品用于 120° 环境下*				

*此环境温度非 CCC 考核范围, 本次 CCC 认证未验证

注: 此附录与证书同时使用时有效。

主任: _____



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>