SIEMENS

Data sheet 6EP1333-1LB00



SITOP PSU100L/1AC/24VDC/5A

SITOP PSU100L 24 V/5 A Stabilized power supply input: 120/230 V AC, output: 24 V DC/5 A

Input	
type of the power supply network	1-phase AC
supply voltage at AC	
initial value	Set by means of selector switch on the device
supply voltage	
 1 at AC rated value 	120 V
 2 at AC rated value 	230 V
input voltage	
• 1 at AC	93 132 V
• 2 at AC	187 264 V
design of input wide range input	No
overvoltage overload capability	2.3 × Vin rated, 1.3 ms
operating condition of the mains buffering	at Vin = 93/187 V
buffering time for rated value of the output current in the event of power failure minimum	20 ms
operating condition of the mains buffering	at Vin = 93/187 V
line frequency	
1 rated value	50 Hz
2 rated value	60 Hz
line frequency	47 63 Hz
input current	
 at rated input voltage 120 V 	2.1 A
 at rated input voltage 230 V 	1.15 A
current limitation of inrush current at 25 °C maximum	32 A
duration of inrush current limiting at 25 °C	
• typical	3 ms
I2t value maximum	0.8 A ² ·s
fuse protection type	T 3,15 A/250 V (not accessible)
• in the feeder	Recommended miniature circuit breaker: from 6 A characteristic C
Output	
voltage curve at output	Controlled, isolated DC voltage
output voltage at DC rated value	24 V
output voltage	
 at output 1 at DC rated value 	24 V
relative overall tolerance of the voltage	3 %
relative control precision of the output voltage	
 on slow fluctuation of input voltage 	0.1 %
 on slow fluctuation of ohm loading 	0.5 %
residual ripple	
• maximum	150 mV
• typical	50 mV
voltage peak	

In season in special adjustable corput voltage adjustable spee of output voltage adjustable spee of output voltage setting adjustable spee of output voltage setting adjustable spee of output voltage setting adjustable spee of output voltage when switching on response delay maximum voltage increase line of the output voltage with a voltage setting of the output voltage with a voltage setting of the output voltage with a voltage setting of the output voltage voltage increase line of the output voltage with a voltage voltage output voltage increase line of the output voltage voltage output voltage vol	• maximum	240 mV
adjustable output voilage product function upout voilage adjustable type of output voilage setting display version for normal operation behavior of the output voilage when switching on response delay maximum voilage increase time of the output voilage 4 yipical autput current 4 craft disuble 6 rated range 10 SA + 45 +60 °C: Denating 2%/K 120 W 120 W 15 A + 45 +60 °C: Denating 2%/K 120 W 17 W 18 Trailed output voilage for rated value of the output voilage in the power Efficiency efficiency in percent power loss (P) 17 W 17 W 17 W 18 Trailed output voilage for rated value of the output voilage for rated value output voilage with rapid fuctuation of the input voilage by +1.15% typical relative control precision of the output voilage with rapid function of the input voilage by +1.15% typical relative control precision of the output voilage with rapid function of the input voilage by +1.15% typical relative control precision of the output voilage at load step of resistive load 10/09/10 % typical eload step 10 to 90% typical eload step 10 to 90% typical eload step 10 to 90% typical eload step 10 to 10% typical voilage output voilage to rated value of the output voilage output voilage to rated value of the output output voilage to y-1.15% typical eload step 10 to 90% t	maximum typical	
product function output votage aguisstable bythe of output votage setting display version for normal operation or response delay maximum votage increase time of the output votage of version for normal operation or response delay maximum votage increase time of the output votage of version for normal operation or response delay maximum votage increase time of the output votage of version for normal operation or response delay maximum votage increase time of the output votage of version of votage of version or version of ver	**	
ype of output voltage setting display version for normal operation behavior of the output voltage when switching on response delay maximum voltage increase time of the output voltage 4 ypical output current 4 rated value 5 A 7 and value 6 rated value 7 rated value 7 rated value 8 religing of equipment 1 runting of parallet-switched equipment resources for 2 runting of parallet-switched equipment resources for 1 runting of parallet-switched equipment resources for 2 runting of switched parallet-switched equipment resources for 2 runting of parallet-switched equipment resources for 2 runting of parallet-switched equipment resources for 3 runting of parallet-switche		
display version for normal operation behavior of the output voltage or nest on the output voltage • typical output current • raded value • raded value • raded range supplied active power typical product feature • Indigency of equipment • rated value • rated range supplied settive power typical product feature • Indigency • or rated value • rated value of parallet-switched equipment resources for noreasing the power Entidency In value • rated value • rated value of the output voltage of rated value of the output relative control precision of the output voltage with rapid fluctuation of the input voltage y-t-16% byteal relative control precision of the output voltage with rapid fluctuation of the input voltage y-t-16% byteal • load step 10 to 90% byteal • load step 10 t		
behavior of the output voltage when switching on response delay maximum 1.5 a		·
response delay maximum voltage • typical output current • rated value • rated value • rated value • rated range • typical product feature • Index fared from the company of the		
voltage increase time of the output voltage * typical output current * rated value * rated va		
Pypical coupled current		1.0 8
output current		130 me
rated value rated range supplied active power typical product feature	• •	130 1115
e rated range supplied active power typical product feature • bindging of equipment product feature • bindging of equipment resources for increasing the power case (Increasing the power feeting power loss) [M] • at rated output voltage for rated value of the output current typical Closed-loop control		5.Δ
suspiled active power typical product feature • bridging of equipment unmber of parallel-switched equipment resources for increasing the power Efficiency ### Efficiency #		
product feature	•	
hindiging of equipment number of parallel-switched equipment resources for increasing the power Fifticiancy		,
number of parallel-switched equipment resources for increasing the power Efficiency efficiency in percent power loss [M] • at rated output voltage for rated value of the output current typical relative control precision of the output voltage with rapid fluctuation of the input voltage by +1- 15% typical relative control precision of the output voltage at load step of resistive load 10/90/10 % typical relative control precision of the output voltage at load step of resistive load 10/90/10 % typical relative control precision of the output voltage at load step of resistive load 10/90/10 % typical relative control precision of the output voltage at load step of resistive load 10/90/10 % typical relative control precision of the output voltage at load step of 10/9 % typical relative control precision of the output voltage with rapid resistive load 10/90/10 % typical relative control precision of the output voltage voltage. **Output file output short-circuit profection **Output file output short-circuit short-circuit profection **Output file output short-circuit **Output file output short-circuit short-circuit **Output file output short-circuit short-circuit short-circuit **Output file output short-circuit short-circuit short-circuit **Output file output short-circuit short	•	Yes
increasing the power Efficiency efficiency in percent power loss [M]		
efficiency in percent power loss [W]		
efficiency in percent power loss [W]	Efficiency	
power loss [W] at rated output voltage for rated value of the output current typical closed-loop control relative control precision of the output voltage with rapid fluctuation of the input voltage by +/- 15% typical relative control precision of the output voltage at load step of resistive load 10/96/10 % typical setting time load step 10 to 90% typical load step 90 to 10% typical load step 90 typical load step 90 to 10% typical load step 90 typical load		86 %
* at rated output voltage for rated value of the output current typical Closed-loop control relative control precision of the output voltage with rapid fluctuation of the input voltage by 4+-15% typical relative control precision of the output voltage at load step of resistive load 10/90/10 % typical relative control precision of the output voltage at load step of resistive load 10/90/10 % typical on 4 ms **load step 10 to 90% typical on 4 ms **load step 90 to 10% typical on 4 ms **load step 90 to 10% typical on 4 ms **protection and monitoring design of the overvoltage protection step 10/10 to 10/10 typical on 10/10 typ		
Clased-loop control relative control precision of the output voltage with rapid fluctuation of the input voltage by 4+- 15% typical relative control precision of the output voltage at load step of resistive load 10;90/10 % typical setting time • load step 10 to 90% typical • load step 90 to 10% typical • load step 90 to 10% typical design of the overvoltage protection • typical design of the overvoltage protection • typical of the overvoltage protection • typical of the output short-circuit proof design of short-circuit protection enduring short-circuit protection • typical display version for overload and short circuit safety galvanic isolation between input and output galvanic isolation between input and output galvanic isolation • typical • typical • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSAA approval • CSAA sproval • CSAA sproval • CSAA sproval • CSA approval • CSAB sproval • LECEX • No • NEC Class 2 • ULhazloc approval • FM registration type of certificate of Suitability • EAC approval FM registration TM T		17 W
relative control precision of the output voltage with rapid fluctuation of the input voltage by +/ 15% typical relative control precision of the output voltage at load step of resistive load 10/90/10 % typical setting time • load step 10 to 90% typical 0.4 ms • load step 90 to 10% typical 0.4 ms • voltage protection and monitoring design of the overvoltage protection 4 typical 5.25 A property of the output short-circuit proof 4 yes constant current characteristic enduring short circuit current RMS value 5.25 A property of the output short-circuit protection 6 the standard short circuit current RMS value 6 typical 7 typical 8 A Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class I leakage current 6 maximum 3.5 mA 6 typical 0.4 mA 7 typi		
fluctuation of the input voltage by +/- 15% typical relative control precision of the output voltage at load step of resistive load 10/90/10 % typical setting time • load step 90 to 10% typical 0.4 ms Protection and monitoring design of the overvoltage protection • typical 5.25 A property of the output short-circuit proof design of short-circuit protection enduring short-circuit protection enduring short circuit current RMS value • typical 5.25 A galvanic isolation between input and output 5.36 ety yersion for overload and short circuit 5.36 ety 9.0 et 3.3 v - safety galvanic isolation between input and output 5.3 ety 9.0 et 3.3 et 3.5 mA • haximum 3.5 mA • typical 0.4 mA protection class IP Approvals certificate of suitability • CE marking 4.9 et 3.0 et	Closed-loop control	
fluctuation of the input voltage by +/- 15% typical relative control precision of the output voltage at load step of resistive load 10/90/10 % typical setting time • load step 90 to 10% typical 0.4 ms Protection and monitoring design of the overvoltage protection • typical 5.25 A property of the output short-circuit proof design of short-circuit protection enduring short-circuit protection enduring short circuit current RMS value • typical 5.25 A galvanic isolation between input and output 5.36 ety yersion for overload and short circuit 5.36 ety 9.0 et 3.3 v - safety galvanic isolation between input and output 5.3 ety 9.0 et 3.3 et 3.5 mA • haximum 3.5 mA • typical 0.4 mA protection class IP Approvals certificate of suitability • CE marking 4.9 et 3.0 et		0.3 %
of resistive load 10/90/10 % typical setting time load step 9 to 10% typical load step 9 to 10% typical load step 9 to 10% typical load step 9 to 10% typical e load step 90 to 10% typical design of the overvoltage protection load step 9 to 10% typical sypical load step 9 to 10% typical load step 9 typical load step 10 typical load step 10 typical load step 10 typical load step 10 typical		
setting time • load step 10 to 90% typical • load step 90 to 10% typical • load step 90 to 10% typical • load step 90 to 10% typical design of the overvoltage protection • lypical • lypical • lypical design of short-circuit proof design of short-circuit protection • lypical design of short-circuit protection • lypical design of short-circuit protection • lypical display version for overload and short circuit - Safety galvanic isolation between input and output galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • lypical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • CSA approval • CSA sproval • CSAs sproval		2 %
• load step 10 to 90% typical • load step 90 to 10% typical • load step 90 to 10% typical design of the overvoltage protection • typical property of the output short-circuit proof design of short-circuit protection • typical safety galvanic isolation between input and output galvanic isolation between input and output galvanic isolation between input and output • typical • maximum • typical		
• load step 90 to 10% typical Protection and monitoring design of the overvoltage protection • typical display version for overload and short circuit • typical display version for overload and short circuit - Safety galvanic isolation between input and output galvanic isolation between input and output • maximum • typical • maximum • typical • maximum • typical • Typical • Typical • CE marking • UL approval • CE marking • UL approval • CSA approval • CSC ultability • IECEx • No • NEC Class 2 • ULhazloc approval • FM registration type of certificate of Suitability • FM registration type of certificate of Suitability • FM registration type of certificate of Suitability • IECEx • No • No • FM registration type of certificate of Suitability • EAC approval • FM registration type of certification CB-certificate certificate of Suitability • EAC approval • FM registration type of certification CB-certificate certificate of Suitability • EAC approval • CSA approval • FM registration type of certification CB-certificate certificate of Suitability • EAC approval • FM registration type of certification cB-certificate certificate of Suitability • EAC approval • FM registration type of certificate of Suitability • EAC approval		
design of the overvoltage protection		
design of the overvoltage protection	● load step 90 to 10% typical	0.4 ms
• typical property of the output short-circuit proof design of short-circuit protection enduring short circuit current RMS value • typical 8 A display version for overload and short circuit safety galvanic isolation between input and output yes galvanic isolation between input and output yes galvanic isolation between input and output yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 (Class I leakage current • maximum	Protection and monitoring	
property of the output short-circuit proof design of short-circuit protection enduring short circuit current RMS value • typical display version for overload and short circuit		< 33 V
design of short-circuit protection enduring short circuit current RMS value • typical display version for overload and short circuit	typical	5.25 A
enduring short circuit current RMS value • typical display version for overload and short circuit	property of the output short-circuit proof	Yes
• typical display version for overload and short circuit		Constant current characteristic
display version for overload and short circuit Safety galvanic isolation between input and output galvanic isolation operating resource protection class Class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • CSA approval • CSA approval • CESAUS, Class 1, Division 2 • ATEX • NEC Class 2 • UL hazloc approval • FM registration type of certificate of suitability • FM registration type of certificate of suitability • FAC approval • CSA approval • CSA approval • STEC Class 2 • Ves • CLESS 2 • Ves • CHIGICATE OF ADAPTION AND • FM registration type of certificate of suitability • EAC approval • CSA approval • CSA certificate of suitability • FM registration type of certificate of suitability • EAC approval • CSA approval	enduring short circuit current RMS value	
galvanic isolation between input and output galvanic isolation between input and output galvanic isolation safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class I leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • CSA, Class 1, Division 2 • ATEX certificate of suitability • IECEx • No • NEC Class 2 • ULhazloc approval • FM registration • PM registration • EAC approval • CSA approval • PM registration • No • EAC approval • PM registration • PM registration • EAC approval • PM registration • PM registration • PM registration • EAC approval • EAC approval • PM registration • PM regi	21	8 A
galvanic isolation between input and output galvanic isolation operating resource protection class leakage current	display version for overload and short circuit	•
galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CSA approval • CSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • No • NEC Class 2 • ULhazloc approval • FM registration type of certificate of suitability • EAC approval • EAC approval • EAC approval Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class I Class I Class I Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class I Class I Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class I Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Safety extra-low class I	Safety	
operating resource protection class leakage current maximum typical protection class IP Approvals certificate of suitability CE marking UL approval CSA approval CSA, Class 1, Division 2 ATEX certificate of suitability IECEx No NEC Class 2 ULhazloc approval FM registration type of certificate of suitability FM registration type of certificate of suitability EAC approval Yes Class I ATEX No Class I Ves Ves Culus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No FM registration No Ves Certificate of suitability FM registration No Ves Certificate of suitability FM registration No Yes Class I	galvanic isolation between input and output	Yes
leakage current maximum typical protection class IP Approvals certificate of suitability CE marking UL approval CSA approval CSA approval CCSAus, Class 1, Division 2 ATEX Certificate of suitability IECEx No NEC Class 2 ULhazloc approval FM registration No type of certificate of suitability EAC approval Yes S.5 mA 0.4 mA IP20 Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No S.6 maximum No No No No No S.7 maximum No No No No S.8 maximum No No Ves Certificate of suitability FM registration No Ves Certificate of suitability FM registration No Type of certification CB-certificate Yes Certificate of suitability FAC approval Yes	galvanic isolation	Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178
 maximum typical 0.4 mA protection class IP IP20 Approvals certificate of suitability CE marking UL approval CSA approval CSA approval CSAus, Class 1, Division 2 ATEX ATEX IECEx No IECEx No FM registration tyes LA approval No EAC approval Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No FM registration No FM registration No type of certification CB-certificate Yes 	operating resource protection class	Class I
 typical protection class IP IP20 Approvals certificate of suitability CE marking UL approval CSA approval CSA approval CSA approval CSA approval CSA (ULs-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 CSA approval CSA (ULs-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 CCSAus, Class 1, Division 2 No ATEX No IECEX NO IECEX NO NO IECEX NO NO FM registration NO type of certification CB-certificate certificate of suitability EAC approval Yes 	leakage current	
protection class IP IP20 Approvals certificate of suitability		
certificate of suitability CE marking UL approval CSA approval CCSAus, Class 1, Division 2 ATEX Certificate of suitability EECEx No NEC Class 2 ULhazloc approval FM registration type of certificate of suitability EAC approval FM certificate of suitability EAC approval FM registration Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; culus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; culus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; culus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; culus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; culus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes; culus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No Tyes		0.4 mA
certificate of suitability CE marking UL approval CSA approval CSA approval CSAus, Class 1, Division 2 ATEX Certificate of suitability IECEx No NEC Class 2 ULhazloc approval FM registration type of certificate of suitability EAC approval EAC approval Yes Yes Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No No No No No Ves Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No No Ves Ves Ves Ves Ves Ves Ves		IP20
 CE marking UL approval CSA approval CSA approval CCSAus, Class 1, Division 2 ATEX ATEX IECEX No NEC Class 2 ULhazloc approval FM registration type of certificate of suitability EAC approval Yes Yes Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No No Yes 	Approvals	
 CE marking UL approval CSA approval CSA approval CCSAus, Class 1, Division 2 ATEX ATEX IECEX No NEC Class 2 ULhazloc approval FM registration type of certificate of suitability EAC approval Yes Yes Yes Yes CULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No No FM registration No Yes 	certificate of suitability	
 UL approval CSA approval CSA approval CCSAus, Class 1, Division 2 ATEX ATEX IECEx No NEC Class 2 ULhazloc approval FM registration type of certificate of suitability EAC approval EAC approval Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes 		Yes
 cCSAus, Class 1, Division 2 ATEX No certificate of suitability IECEx No NEC Class 2 ULhazloc approval FM registration type of certification CB-certificate certificate of suitability EAC approval Yes 	 UL approval 	Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259
 ATEX certificate of suitability IECEX NO NEC Class 2 ULhazloc approval FM registration type of certification CB-certificate certificate of suitability EAC approval No Yes 	 CSA approval 	Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259
certificate of suitability IECEX No NEC Class 2 ULhazloc approval FM registration type of certification CB-certificate certificate of suitability EAC approval No Yes	 cCSAus, Class 1, Division 2 	No
 IECEx NEC Class 2 ULhazloc approval FM registration type of certification CB-certificate certificate of suitability EAC approval No Yes 	• ATEX	No
 NEC Class 2 ULhazloc approval FM registration type of certification CB-certificate certificate of suitability EAC approval No Yes 	certificate of suitability	
 ULhazloc approval FM registration type of certification CB-certificate certificate of suitability EAC approval No No Yes 		No
 FM registration type of certification CB-certificate certificate of suitability EAC approval No Yes 	NEC Class 2	No
type of certification CB-certificate certificate of suitability • EAC approval Yes Yes		
ecrtificate of suitability ■ EAC approval Yes	_	No
EAC approval Yes		Yes
certificate of suitability shipbuilding approval		
	certificate of suitability shipbuilding approval	No

ahinhuilding approval	
shipbuilding approval Marine classification association	
American Bureau of Shipping Europe Ltd. (ABS)	No
French marine classification society (BV)	No
DNV GL	No
Lloyds Register of Shipping (LRS)	No
Nippon Kaiji Kyokai (NK)	No
EMC	140
standard	
for emitted interference	EN 55022 Class A
for mains harmonics limitation	-
for interference immunity	EN 61000-6-2
environmental conditions	2.1.0.00002
ambient temperature	
during operation	0 60 °C; with natural convection
during operation during transport	-40 +85 °C
during storage	-40 +85 °C
environmental category according to IEC 60721	Climate class 3K3, 5 95% no condensation
Mechanics	
type of electrical connection	screw-type terminals
• at input	L, N, PE: 1 screw terminal each for 0.5 2.5 mm² single-core/finely stranded
at output	+, -: 2 screw terminals each for 0.5 2.5 mm ²
for auxiliary contacts	-
width of the enclosure	50 mm
height of the enclosure	125 mm
depth of the enclosure	120 mm
required spacing	
• top	50 mm
• bottom	50 mm
• left	0 mm
• right	0 mm
net weight	0.5 kg
product feature of the enclosure housing can be lined up	Yes
fastening method	Snaps onto DIN rail EN 60715 35x7.5/15
MTBF at 40 °C	3 076 166 h
other information	Specifications at rated input voltage and ambient temperature +25 °C (unless otherwise specified)

