SIEMENS

Data sheet

3RW4027-1BB04



SIRIUS soft starter S0 32 A, 15 kW/400 V, 40 $^\circ\text{C}$ 200-480 V AC, 24 V AC/DC Screw terminals

General technical data		
product brand name		SIRIUS
product feature		
 integrated bypass contact system 		Yes
thyristors		Yes
product function		
 intrinsic device protection 		Yes
 motor overload protection 		Yes
 evaluation of thermistor motor protection 		No
external reset		Yes
 adjustable current limitation 		Yes
 inside-delta circuit 		No
product component motor brake output		No
insulation voltage rated value	V	600
degree of pollution		3, acc. to IEC 60947-4-2
reference code according to EN 61346-2		Q
reference code according to DIN 40719 extended according to IEC 204-2 according to IEC 750		G
Power Electronics		
product designation		Soft starter
operational current		
 at 40 °C rated value 	А	32
 at 50 °C rated value 	A	29
 at 60 °C rated value 	A	26
yielded mechanical performance for 3-phase motors		
• at 230 V		
 — at standard circuit at 40 °C rated value 	kW	7.5
• at 400 V		
 — at standard circuit at 40 °C rated value 	kW	15
yielded mechanical performance [hp] for 3-phase AC motor at 200/208 V at standard circuit at 50 °C rated value	hp	7.5
operating frequency rated value	Hz	50 60
relative negative tolerance of the operating frequency	%	-10
relative positive tolerance of the operating frequency	%	10
operating voltage at standard circuit rated value	V	200 480
relative negative tolerance of the operating voltage at standard circuit	%	-15
relative positive tolerance of the operating voltage at standard circuit	%	10
minimum load [%]	%	20
adjustable motor current for motor overload protection minimum rated value	А	17


continuous operating current [% of le] at 40 °C power loss [W] at operational current at 40 °C during % 115 W 13


power loss [W] at operational current at 40 °C during operation typical	W	13
Control circuit/ Control		
type of voltage of the control supply voltage		AC/DC
	Hz	50
control supply voltage frequency 1 rated value control supply voltage frequency 2 rated value	Hz	60
	⊓∠ %	-10
relative negative tolerance of the control supply voltage frequency		
relative positive tolerance of the control supply voltage frequency	%	10
control supply voltage 1 at AC		
 at 50 Hz rated value 	V	24
 at 60 Hz rated value 	V	24
relative negative tolerance of the control supply voltage at AC at 50 Hz	%	-15
relative positive tolerance of the control supply voltage at AC at 50 Hz	%	10
relative negative tolerance of the control supply voltage at AC at 60 Hz	%	-15
relative positive tolerance of the control supply voltage at AC at 60 Hz	%	10
control supply voltage 1 at DC rated value	V	24
relative negative tolerance of the control supply voltage at DC	%	-20
relative positive tolerance of the control supply voltage at DC	%	20
display version for fault signal		red
Mechanical data		
size of engine control device		S0
width	mm	45
height	mm	125
depth	mm	155
fastening method		screw and snap-on mounting
mounting position		With additional fan: With vertical mounting surface +/-90° rotatable, with vertical mounting surface +/- 22.5° tiltable to the front and back Without additional fan: With vertical mounting surface +/- 10° rotatable, with vertical mounting surface +/- 10° t
required spacing with side-by-side mounting		
• upwards	mm	60
• at the side	mm	15
downwards	mm	40
wire length maximum	m	300
number of poles for main current circuit		3
Connections/ Terminals		
type of electrical connection		
for main current circuit		screw-type terminals
for auxiliary and control circuit		screw-type terminals
number of NC contacts for auxiliary contacts		0
number of NO contacts for auxiliary contacts		2
number of CO contacts for auxiliary contacts		-
type of connectable conductor cross-sections for main contacts for box terminal using the front clamping point		
• solid		2x (1 2.5 mm ²), 2x (2.5 6 mm ²), max. 1x 10 mm ²
 finely stranded with core end processing 		2x (1 2.5 mm ²), 2x (2.5 6 mm ²)
type of connectable conductor cross-sections at AWG cables for main contacts for box terminal		
 using the front clamping point 		1x 8, 2x (16 10)
type of connectable conductor cross-sections for auxiliary contacts		
• solid		2x (0.5 2.5 mm²)
 finely stranded with core end processing 		2x (0.5 1.5 mm ²)
type of connectable conductor cross-sections at AWG cables		
 for auxiliary contacts 		2x (20 14)

 for auxiliary cor processing 	ntacts finely stranded w	ith core end		2x (20 16)		
Ambient conditions						
installation altitude environmental categoria	at height above sea le	evel	m	5 000		
•	t according to IEC 6072	21		2K2 2C1 2S1	, 2M2 (max. fall height 0) 3 m)
	according to IEC 60721				asional condensation), 1	· ·
		<u>I</u>			st not get inside the devi	
 during operatio 	n according to IEC 607	21		3K6 (no forma	tion of ice, no condensati nd must not get into the	tion), 3C3 (no salt
ambient temperatur	е			, ,	-	,
 during operatio 	n		°C	-25 +60		
during storage			°C	-40 +80		
derating temperatur	е		°C	40		
	on the front according	to IEC		IP20		
touch protection on	the front according to	o IEC 60529		finger-safe, for	vertical contact from the	e front
Certificates/ approval	ls					
General Product Ap	oproval					EMC
	\frown	Confirmatio	on	\frown		~
(56)	(\mathbf{m})		<u></u>	(1)		le la companya de la comp
W				S.	ΓΠΙ	Ś
CSA	ccc			UL		RCM
Declaration of Conf	formity	Test Certifica	ates		Marine / Shipping	
Doolaration of com	lonnity				indinio, empping	
		Special Test C	ertific- Type	e Test Certific-		STA
()	UK	ate		s/Test Report	Lloyds	(33)
					register	C ARE
EG-Konf.	LН				LRS	PRS
Marino / Shinning	other	Railway				
Marine / Shipping	other	Railway				
Marine / Shipping			מר			
Marine / Shipping	other Confirmation	Railway Confirmatio	<u>on</u>			
Marine / Shipping			<u>on</u>			
Marine / Shipping			<u>on</u>			
Marine / Shipping			<u>on</u>			
Marine / Shipping			<u>on</u>			
			<u>2n</u>			
UL/CSA ratings	Confirmation	Confirmatio	<u>n</u>			
UL/CSA ratings yielded mechanical		Confirmatio	<u>n</u>			
UL/CSA ratings yielded mechanical motor	Confirmation	Confirmatio	<u>on</u>			
UL/CSA ratings yielded mechanical motor • at 220/230 V	Confirmation performance [hp] for	Confirmation				
UL/CSA ratings yielded mechanical motor • at 220/230 V — at standar	Confirmation	Confirmation	<u>on</u> hp	7.5		
UL/CSA ratings yielded mechanical motor • at 220/230 V — at standar • at 460/480 V	Confirmation Confirmation performance [hp] for d circuit at 50 °C rated	Confirmation	hp			
UL/CSA ratings yielded mechanical motor • at 220/230 V — at standar • at 460/480 V — at standar	Confirmation Confirmation performance [hp] for d circuit at 50 °C rated d circuit at 50 °C rated	Confirmation		20		
UL/CSA ratings yielded mechanical motor • at 220/230 V — at standar • at 460/480 V — at standar contact rating of au	Confirmation Confirmation performance [hp] for d circuit at 50 °C rated	Confirmation	hp			
UL/CSA ratings yielded mechanical motor • at 220/230 V — at standar • at 460/480 V — at standar	Confirmation Confirmation performance [hp] for d circuit at 50 °C rated d circuit at 50 °C rated	Confirmation	hp	20		
UL/CSA ratings yielded mechanical motor • at 220/230 V — at standar • at 460/480 V — at standar contact rating of au Further information Siemens has decide	Confirmation performance [hp] for d circuit at 50 °C rated d circuit at 50 °C rated xiliary contacts accord ed to exit the Russian	Confirmation Confi	hp hp re).	20 B300 / R300		
UL/CSA ratings yielded mechanical motor • at 220/230 V at standar • at 460/480 V at standar contact rating of aux Further information Siemens has decide https://press.siemens	Confirmation performance [hp] for d circuit at 50 °C rated d circuit at 50 °C rated xiliary contacts accord ed to exit the Russian 5.com/global/en/pressre	Confirmation Confi	hp hp re). <i>r</i> ind-down-ruse	20 B300 / R300		
UL/CSA ratings yielded mechanical motor • at 220/230 V — at standar • at 460/480 V — at standar contact rating of au Further information Siemens has decide https://press.siemens Siemens is working	Confirmation performance [hp] for d circuit at 50 °C rated d circuit at 50 °C rated xiliary contacts accord ed to exit the Russian com/global/en/pressre on the renewal of the	Confirmation Confi	hp hp re). <u>vind-down-rus</u> : ertificates.	20 B300 / R300 sian-business		
UL/CSA ratings yielded mechanical motor • at 220/230 V — at standar • at 460/480 V — at standar contact rating of au Further information Siemens has decide https://press.siemens Siemens is working Please contact your lo	Confirmation performance [hp] for d circuit at 50 °C rated d circuit at 50 °C rated xiliary contacts accorr ed to exit the Russian com/global/en/pressre on the renewal of the ocal Siemens office on	Confirmation Confi	hp hp re). vind-down-rus: ertificates. dity of the EA	20 B300 / R300 sian-business C certification if y	ou intend to import or of	fer to supply these
UL/CSA ratings yielded mechanical motor • at 220/230 V — at standar • at 460/480 V — at standar contact rating of au Further information Siemens has decide https://press.siemens Siemens is working Please contact your le products to an EAC re	Confirmation performance [hp] for d circuit at 50 °C rated d circuit at 50 °C rated xiliary contacts accord acto exit the Russian a.com/global/en/pressre on the renewal of the ocal Siemens office on elevant market (other th	Confirmation Confi	hp hp re). vind-down-rus: ertificates. dity of the EA	20 B300 / R300 sian-business C certification if y	rou intend to import or of ia or Belarus).	fer to supply these
UL/CSA ratings yielded mechanical motor • at 220/230 V — at standar • at 460/480 V — at standar contact rating of au Further information Siemens has decide https://press.siemens Siemens is working Please contact your le products to an EAC re Simulation Tool for	Confirmation performance [hp] for d circuit at 50 °C rated d circuit at 50 °C rated xiliary contacts accord acto exit the Russian a.com/global/en/pressre on the renewal of the ocal Siemens office on elevant market (other th	Confirmation Confi	hp hp re). <u>vind-down-russ</u> ertificates. dity of the EA ed EAEU men	20 B300 / R300 sian-business C certification if y	rou intend to import or of ia or Belarus).	fer to supply these
UL/CSA ratings yielded mechanical motor • at 220/230 V — at standar • at 460/480 V — at standar contact rating of au Further information Siemens has decide https://press.siemens Siemens is working Please contact your le products to an EAC re Simulation Tool for https://support.industr Information on the p	Confirmation performance [hp] for d circuit at 50 °C rated d circuit at 50 °C rated xiliary contacts accorr ed to exit the Russian com/global/en/pressre on the renewal of the ocal Siemens office on elevant market (other th Soft Starters (STS) ry.siemens.com/cs/ww/ backaging	Confirmation Confi	hp hp re). vind-down-russ ertificates. dity of the EA ed EAEU men 217	20 B300 / R300 sian-business C certification if y	rou intend to import or of ia or Belarus).	fer to supply these
UL/CSA ratings yielded mechanical motor • at 220/230 V — at standar • at 460/480 V — at standar contact rating of au: Further information Siemens has decide https://press.siemens Siemens is working Please contact your le products to an EAC ro Simulation Tool for https://support.industri Information on the p	Confirmation performance [hp] for d circuit at 50 °C rated d circuit at 50 °C rated xiliary contacts accorr ed to exit the Russian com/global/en/pressre on the renewal of the ocal Siemens office on elevant market (other th Soft Starters (STS) ry.siemens.com/cs/ww/ packaging ry.siemens.com/cs/ww/	Confirmation Co	hp hp re). vind-down-russ ertificates. dity of the EA ed EAEU men 217 375	20 B300 / R300 sian-business C certification if y	rou intend to import or of ia or Belarus).	fer to supply these
UL/CSA ratings yielded mechanical motor • at 220/230 V — at standar • at 460/480 V — at standar contact rating of au Further information Siemens has decide https://press.siemens Siemens is working Please contact your le products to an EAC re Simulation Tool for https://support.industr Information on the p https://support.industr	Confirmation performance [hp] for d circuit at 50 °C rated d circuit at 50 °C rated xiliary contacts accord ed to exit the Russian com/global/en/pressre on the renewal of the ocal Siemens office on elevant market (other th Soft Starters (STS) ry.siemens.com/cs/ww/ backaging ry.siemens.com/cs/ww/ ownloadcenter (Catalo	Confirmation Co	hp hp re). vind-down-russ ertificates. dity of the EA ed EAEU men 217 375	20 B300 / R300 sian-business C certification if y	rou intend to import or of ia or Belarus).	fer to supply these
UL/CSA ratings yielded mechanical motor • at 220/230 V — at standar • at 460/480 V — at standar contact rating of au Further information Siemens has decide https://press.siemens Siemens is working Please contact your le products to an EAC re Simulation Tool for https://support.industr Information on the p https://support.industr Information and Do https://www.siemens.	Confirmation performance [hp] for d circuit at 50 °C rated d circuit at 50 °C rated xiliary contacts accord ed to exit the Russian accom/global/en/pressre on the renewal of the ocal Siemens office on elevant market (other th Soft Starters (STS) ry.siemens.com/cs/ww/ backaging ry.siemens.com/cs/ww/ backaging ry.siemens.com/cs/ww/ backaging	Confirmation Co	hp hp re). vind-down-russ ertificates. dity of the EA ed EAEU men 217 375	20 B300 / R300 sian-business C certification if y	rou intend to import or of ia or Belarus).	fer to supply these
UL/CSA ratings yielded mechanical motor • at 220/230 V — at standar • at 460/480 V — at standar contact rating of au: Further information Siemens has decide https://press.siemens Siemens is working Please contact your le products to an EAC re Simulation Tool for https://support.industr Information on the p https://support.industr Information- and Do https://www.siemens. Industry Mall (Online	Confirmation performance [hp] for d circuit at 50 °C rated d circuit at 50 °C rated xiliary contacts accord ed to exit the Russian accom/global/en/pressre on the renewal of the ocal Siemens office on elevant market (other th Soft Starters (STS) ry.siemens.com/cs/ww/ backaging ry.siemens.com/cs/ww/ backaging ry.siemens.com/cs/ww/ backaging	Confirmation 3-phase AC value value ding to UL market (see here lease/siemens-w current EAC content the status of valition current EAC content the status of valition the status of valitio	hp hp re). vind-down-russ ertificates. dity of the EAt ed EAEU men 217 375)	20 B300 / R300 sian-business C certification if y aber states Russi	rou intend to import or of ia or Belarus).	fer to supply these

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RW4027-1BB04 Service&Support (Manuals, Certificates, Characteristics, FAQs,...) https://support.industry.siemens.com/cs/ww/en/ps/3RW4027-1BB04 Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3RW4027-1BB04&lang=en





last modified:

10/28/2022 🖸