SIEMENS

Data sheet

6ES7151-7AA21-0AB0



SIMATIC DP, IM151-7 CPU for ET200S, 128 KB work memory with integrated PROFIBUS DP interface (9-pole D-sub socket) as DP slave, without battery SIMATIC MMC required

General information	
HW functional status	01
Firmware version	V3.3
Product function	
Isochronous mode	No
Engineering with	
 Programming package 	as of STEP 7 V5.5 + SP1 or as of V5.2 + SP1 + HSP 219 or as of STEP 7 TIA Portal V11
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes; against destruction
external protection for power supply lines (recommendation)	2 A min.
Mains buffering	
 Mains/voltage failure stored energy time 	5 ms
Input current	
Inrush current, typ.	1.8 A
l²t	0.09 A ² ·s
from supply voltage 1L+, max.	320 mA; 410 mA with DP master module
Output current	
for backplane bus (5 V DC), max.	700 mA
Power loss	
Power loss, typ.	4.2 W
Memory	
Work memory	
 integrated 	128 kbyte
expandable	No
Load memory	
• Plug-in (MMC)	Yes
 Plug-in (MMC), max. 	8 Mbyte
 Data management on MMC (after last programming), min. 	10 a
Backup	
present	Yes; Ensured by SIMATIC Micro Memory Card (maintenance-free)
CPU processing times	
for bit operations, typ.	0.06 µs
for word operations, typ.	0.12 µs
for fixed point arithmetic, typ.	0.16 µs
for floating point arithmetic, typ.	0.59 µs

CPU-blocks	
Number of blocks (total)	1 024; (DBs, FCs, FBs); the maximum number of loadable blocks can
	be reduced by the MMC used.
DB	
 Number, max. 	1 024; Number range: 1 to 16000
• Size, max.	64 kbyte
FB	
• Number, max.	1 024; Number range: 0 to 7999
• Size, max.	64 kbyte
FC • Number, max.	1.024: Number range: 0 to 7000
• Size, max.	1 024; Number range: 0 to 7999 64 kbyte
OB	04 Royle
Number, max.	See S7-300 operation list
• Size, max.	64 kbyte
Number of free cycle OBs	1; OB 1
 Number of time alarm OBs 	1; OB 10
 Number of delay alarm OBs 	2; OB 20, 21
Number of cyclic interrupt OBs	4; OB 32, 33, 34, 35
Number of process alarm OBs	1; OB 40
Number of DPV1 alarm OBs	3; OB 55, 56, 57
Number of startup OBs	1; OB 100
 Number of asynchronous error OBs 	6; OB 80, 82, 83 (for centralized I/O only, not for distributed I/O), 85, 86,
Number of our 1 CD	87
Number of synchronous error OBs	2; OB 121, 122
Nesting depth	16
 per priority class additional within an error OB 	4
	4
Counters, timers and their retentivity	
S7 counter	250
Number Detentivity	256
Retentivity — adjustable	Yes
— lower limit	0
— upper limit	255
— preset	Z 0 to Z 7
Counting range	
— lower limit	0
— upper limit	999
IEC counter	
• present	Yes
• Туре	SFB
Number	Unlimited (limited only by RAM capacity)
S7 times	
• Number	256
Retentivity	Vee
— adjustable	Yes
— lower limit	0 255
— upper limit — preset	255 No retentivity
Time range	No recentivity
— lower limit	10 ms
— upper limit	9 990 s
IEC timer	
• present	Yes
• Туре	SFB
• Number	Unlimited (limited only by RAM capacity)
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	64 kbyte
Flag	
• Size, max.	256 byte
Retentivity available	Yes; MB 0 to MB 255
Retentivity preset	MB 0 to MB 15
 Number of clock memories 	8; 1 memory byte

Data blocks	
Retentivity adjustable	Yes; via non-retain property on DB
Retentivity preset	Yes
Local data	
 per priority class, max. 	32 kbyte; Max. 2048 bytes per block
Address area	
I/O address area	
Inputs	2 048 byte
Outputs	2 048 byte
of which distributed	
— Inputs	2 048 byte
— Outputs	2 048 byte
Process image	
Inputs	2 048 byte
Outputs	2 048 byte
Inputs, adjustable	2 048 byte
Outputs, adjustable	2 048 byte
Inputs, default	128 byte
Outputs, default Digital channels	128 byte
Inputs	16 336
of which central	496
Outputs	16 336
— of which central	496
Analog channels	
• Inputs	1 021
— of which central	124
Outputs	1 021
— of which central	124
Hardware configuration	
Number of modules per system, max.	63; Centralized
Mounting rail	
 Number of mounting rails that can be used 	1
 Length of mounting rail, max. 	
- Longar of mounting run, max.	Station width: \leq 1 m or $<$ 2 m
Time of day	Station width: $\leq 1 \text{ m or } < 2 \text{ m}$
	Station width: ≤ 1 m or < 2 m
Time of day	Station width: ≤ 1 m or < 2 m Yes
Time of day Clock	
Time of day Clock • Hardware clock (real-time)	Yes
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max.	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period Operating hours counter	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period Operating hours counter • Number	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period Operating hours counter • Number • Number • Number range	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period Operating hours counter • Number • Number • Range of values	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period Operating hours counter • Number • Number • Number range	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101)
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period Operating hours counter • Number • Number • Number range • Range of values • Granularity	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h
Time of day Clock Hardware clock (real-time) retentive and synchronizable Backup time Deviation per day, max. Behavior of the clock following POWER-ON Behavior of the clock following expiry of backup period Operating hours counter Number Number Range of values Granularity retentive	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h
Time of day Clock Hardware clock (real-time) retentive and synchronizable Backup time Deviation per day, max. Behavior of the clock following POWER-ON Behavior of the clock following expiry of backup period Operating hours counter Number Number Range of values Granularity retentive Clock synchronization	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period Operating hours counter • Number • Number/Number range • Range of values • Granularity • retentive Clock synchronization • supported	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart Yes
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period Operating hours counter • Number • Number • Number/Number range • Range of values • Granularity • retentive Clock synchronization • supported • to MPI, master • to DP, master	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart Yes Yes Yes Yes; With DP slave only slave clock
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period Operating hours counter • Number • Number • Number/Number range • Range of values • Granularity • retentive Clock synchronization • supported • to MPI, master • to DP, master • to DP, slave	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart Yes Yes Yes Yes Yes; With DP slave only slave clock Yes
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period Operating hours counter • Number • Number • Number • Number/Number range • Range of values • Granularity • retentive Clock synchronization • supported • to MPI, master • to MPI, slave • to DP, master • to DP, slave • in AS, master	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart Yes Yes Yes Yes; With DP slave only slave clock Yes No
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period Operating hours counter • Number • Number • Number • Number/Number range • Range of values • Granularity • retentive Clock synchronization • supported • to MPI, master • to MPI, slave • to DP, master • to DP, slave • in AS, master • in AS, slave	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart Yes Yes Yes Yes Yes; With DP slave only slave clock Yes
Time of day Clock Hardware clock (real-time) retentive and synchronizable Backup time Deviation per day, max. Behavior of the clock following POWER-ON Behavior of the clock following expiry of backup period Operating hours counter Number Number Number/Number range Range of values Granularity retentive Clock synchronization supported to MPI, master to DP, master to DP, slave in AS, master	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart Yes Yes Yes Yes; With DP slave only slave clock Yes No No
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period Operating hours counter • Number • Number • Number/Number range • Range of values • Granularity • retentive Clock synchronization • supported • to MPI, master • to MPI, slave • to DP, master • to DP, slave • in AS, master • in AS, slave Interfaces/bus type	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart Yes Yes Yes Yes; With DP slave only slave clock Yes No
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period Operating hours counter • Number • Number • Number/Number range • Range of values • Granularity • retentive Clock synchronization • supported • to MPI, master • to MPI, slave • to DP, master • to DP, slave • in AS, master • in AS, slave	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart Yes Yes Yes Yes; With DP slave only slave clock Yes No No
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period Operating hours counter • Number • Number • Number/Number range • Range of values • Granularity • retentive Clock synchronization • supported • to MPI, master • to MPI, slave • to DP, master • to DP, slave • in AS, master • in AS, slave Interfaces/bus type	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart Yes Yes Yes Yes; With DP slave only slave clock Yes No No
Time of day Clock • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period Operating hours counter • Number • Number/Number range • Range of values • Granularity • retentive Clock synchronization • supported • to MPI, master • to DP, slave • in AS, master • in AS, slave Interfaces/bus type	Yes Yes 6 wk; At 40 °C ambient temperature, typically 10 s; Typ.: 2 s Clock continues running after POWER OFF the clock continues at the time of day it had when power was switched off 1 0 0 to 2^31 hours (when using SFC 101) 1 h Yes; Must be restarted at each restart Yes Yes Yes Yes Yes; With DP slave only slave clock Yes No No No

• RS 485	Yes
 Output current of the interface, max. 	80 mA
Protocols	
• MPI	Yes
PROFIBUS DP master	No
PROFIBUS DP slave	Yes; active / passive
Point-to-point connection	No
MPI	
Transmission rate, max.	12 Mbit/s
Services	
— PG/OP communication	Yes
— Routing	Yes; With master module
— Global data communication	Yes
- S7 basic communication	Yes
— S7 communication	Yes; Only server, configured on one side
- S7 communication, as client	No
- S7 communication, as server	Yes
PROFIBUS DP slave	
GSD file	The latest GSD file is available on the Internet
	(http://www.siemens.com/profibus-gsd)
Transmission rate, max.	12 Mbit/s
 automatic baud rate search 	Yes; only with passive interface
 Address area, max. 	32
 User data per address area, max. 	32 byte; Up to max. size of the transfer memory
Services	
— PG/OP communication	Yes
— Routing	Yes; Only with active, integrated DP slave interface and inserted DP master module in DP master mode
 Global data communication 	No
 — S7 basic communication 	No
— S7 communication	Yes; Only server, configured on one side
- S7 communication, as client	No
 — S7 communication, as server 	Yes
 — Direct data exchange (slave-to-slave communication) 	Yes
— DPV1	No
Transfer memory	
— Inputs	244 byte
— Outputs	244 byte
2. Interface	
Interface type	External interface via master module 6ES7138-4HA00-0AB0
Isolated	Yes
Interface types	
• RS 485	Yes
 Output current of the interface, max. 	No
Protocols	
• MPI	No
 PROFIBUS DP master 	Yes
PROFIBUS DP slave	No
PROFIBUS DP master	
• Transmission rate, max.	12 Mbit/s
Number of DP slaves, max.	32; Per station
Services	
— PG/OP communication	Yes
- Routing	Yes
— Global data communication	No
— S7 basic communication	Yes; I blocks only
— S7 communication	Yes; Only server, configured on one side
— S7 communication, as client	No
— S7 communication, as server	Yes
— Equidistance	Yes
•	
— Isochronous mode	No
•	No Yes Yes

 Number of DP slaves that can be 	8
simultaneously activated/deactivated, max.	
 — Direct data exchange (slave-to-slave 	Yes
communication)	
— DPV1	Yes
Address area	
— Inputs, max.	2 kbyte
— Outputs, max.	2 kbyte
User data per DP slave	
— Inputs, max.	244 byte
— Outputs, max.	244 byte
· ·	211 5/10
Protocols	
Open IE communication	
• TCP/IP	No
communication functions / header	
PG/OP communication	Yes
	Yes; With DP master module
Data record routing	res, with Dr master module
Global data communication	
• supported	Yes
 Number of GD loops, max. 	8
 Number of GD packets, max. 	8
 Number of GD packets, transmitter, max. 	8
Number of GD packets, receiver, max.	8
 Size of GD packets, max. 	22 byte
• Size of GD packet (of which consistent), max.	22 byte
S7 basic communication	
	Yes
• supported	
User data per job, max.	76 byte
 User data per job (of which consistent), max. 	76 byte; 76 bytes (with X_SEND or X_RCV); 64 bytes (with X_PUT or
	X_GET as server)
S7 communication	
 supported 	Yes
• as server	Yes
 as client 	No
 User data per job, max. 	See online help of STEP 7 (shared parameters of the SFBs/FBs and of
	the SFCs/FCs of S7 Communication)
 User data per job (of which consistent), max. 	See online help of STEP 7 (shared parameters of the SFBs/FBs and of
	the SFCs/FCs of S7 Communication)
Number of connections	
overall	12
 usable for PG communication 	11
- reserved for PG communication	1
	1
 adjustable for PG communication, min. 	
— adjustable for PG communication, max.	11
 usable for OP communication 	11
 reserved for OP communication 	1
 adjustable for OP communication, min. 	1
 adjustable for OP communication, max. 	11
 usable for S7 basic communication 	10
 reserved for S7 basic communication 	0
— adjustable for S7 basic communication, min.	0
— adjustable for S7 basic communication, max.	10
-	
usable for routing	4; As slave only with active interface, with IM 151-7 CPU as DP master
S7 message functions	
Number of login stations for message functions, max.	12; Depending on the configured connections for PG/OP and S7 basic
	communication
Process diagnostic messages	Yes; ALARM_S, ALARM_SC, ALARM_SQ, ALARM_D, ALARM_DQ
simultaneously active Alarm-S blocks, max.	300
Test commissioning functions	
Status block	Yes; Up to 2 simultaneously
Single step	Yes
Number of breakpoints	4
Status/control	
 Status/control variable 	Yes

Variables	Inputs, outputs, memory bits, DB, times, counters
Number of variables, max.	30
— of which status variables, max.	30
— of which control variables, max.	14
Forcing	
ForcingForcing, variables	Yes Inputs, outputs
Number of variables, max.	10
Diagnostic buffer	
• present	Yes
 Number of entries, max. 	500
— adjustable	No
— of which powerfail-proof	100; Only the last 100 entries are retained
Number of entries readable in RUN, max.	499
— adjustable — preset	Yes; From 10 to 499 10
Service data	10
• can be read out	Yes
Interrupts/diagnostics/status information	
Alarms	Yes
Diagnostics function	Yes
Diagnostics indication LED	
 Group error SF (red) 	Yes
 Monitoring 24 V voltage supply ON (green) 	Yes
Potential separation	
between PROFIBUS DP and all other circuit components	Yes
Isolation	
Isolation tested with	500 V DC
Degree and class of protection	
IP degree of protection	IP20
configuration / header	
Configuration rules	max. 63 peripheral modules per station; station width < 1 m or < 2 m; max. 10 A per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface)
Configuration rules Configuration software	max. 10 A per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface)
Configuration rules Configuration software • STEP 7 Lite	max. 10 A per load group (power module); master interface module on
Configuration rules Configuration software • STEP 7 Lite configuration / programming / header	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface)
Configuration rules Configuration software • STEP 7 Lite configuration / programming / header • Command set	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list
Configuration rules Configuration software • STEP 7 Lite configuration / programming / header • Command set • Nesting levels	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface)
Configuration rules Configuration software • STEP 7 Lite configuration / programming / header • Command set	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8
Configuration rules Configuration software • STEP 7 Lite configuration / programming / header • Command set • Nesting levels • System functions (SFC)	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8 see instruction list
Configuration rules Configuration software • STEP 7 Lite configuration / programming / header • Command set • Nesting levels • System functions (SFC) • System function blocks (SFB) Programming language — LAD	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8 see instruction list
Configuration rules Configuration software • STEP 7 Lite configuration / programming / header • Command set • Nesting levels • System functions (SFC) • System function blocks (SFB) Programming language — LAD — FBD	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8 see instruction list see instruction list Yes Yes
Configuration rules Configuration software • STEP 7 Lite configuration / programming / header • Command set • Nesting levels • System functions (SFC) • System function blocks (SFB) Programming language - LAD - FBD - STL	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8 see instruction list see instruction list Yes Yes Yes
Configuration rules Configuration software • STEP 7 Lite configuration / programming / header • Command set • Nesting levels • System functions (SFC) • System function blocks (SFB) Programming language - LAD - FBD - STL - SCL	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8 see instruction list see instruction list Yes Yes Yes Yes; Optional
Configuration rules Configuration software • STEP 7 Lite configuration / programming / header • Command set • Nesting levels • System functions (SFC) • System function blocks (SFB) Programming language — LAD — FBD — STL — SCL — CFC	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8 see instruction list see instruction list Yes Yes Yes Yes Yes; Optional Yes; Optional
Configuration rules Configuration software • STEP 7 Lite configuration / programming / header • Command set • Nesting levels • System functions (SFC) • System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8 see instruction list see instruction list Yes Yes Yes Yes Yes; Optional Yes; Optional Yes; Optional
Configuration rules Configuration software • STEP 7 Lite configuration / programming / header • Command set • Nesting levels • System functions (SFC) • System function blocks (SFB) Programming language — LAD — FBD — STL — SCL — CFC	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8 see instruction list see instruction list Yes Yes Yes Yes Yes; Optional Yes; Optional
Configuration rules Configuration software • STEP 7 Lite configuration / programming / header • Command set • Nesting levels • System functions (SFC) • System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph®	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8 see instruction list see instruction list Yes Yes Yes Yes Yes; Optional Yes; Optional Yes; Optional
Configuration rules Configuration software STEP 7 Lite Configuration / programming / header Command set Nesting levels System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® Know-how protection User program protection/password protection Block encryption	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8 see instruction list see instruction list Yes Yes Yes Yes Yes; Optional Yes; Optional Yes; Optional Yes; Optional
Configuration rules Configuration software STEP 7 Lite Configuration / programming / header Command set Nesting levels System functions (SFC) System function blocks (SFB) Programming language - LAD - FBD - STL - SCL - CFC - GRAPH - HiGraph® Know-how protection User program protection/password protection Block encryption programming / cycle time monitoring / header	 max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8 see instruction list see instruction list Yes Yes Yes Yes; Optional
Configuration rules Configuration software STEP 7 Lite Configuration / programming / header Command set Nesting levels System functions (SFC) System function blocks (SFB) Programming language - LAD - FBD - STL - SCL - CFC - GRAPH - HiGraph® Know-how protection Block encryption programming / cycle time monitoring / header I lower limit	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8 see instruction list see instruction list Yes Yes Yes Yes Yes; Optional Yes; With S7 block Privacy
Configuration rules Configuration software STEP 7 Lite Configuration / programming / header Command set Nesting levels System functions (SFC) System function blocks (SFB) Programming language	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8 see instruction list see instruction list Yes Yes Yes Yes; Optional Yes; Optional Yes; Optional Yes; Optional Yes; Optional Yes; Optional Yes; Optional Yes; Optional
Configuration rules Configuration software STEP 7 Lite configuration / programming / header Command set Nesting levels System functions (SFC) System function blocks (SFB) Programming language	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8 see instruction list see instruction list Yes Yes Yes Yes; Optional Yes; Optional Yes; Optional Yes; Optional Yes; Optional Yes; With S7 block Privacy
Configuration rules Configuration software STEP 7 Lite configuration / programming / header Command set Nesting levels System functions (SFC) System function blocks (SFB) Programming language - LAD - FBD - STL - SCL - CFC - GRAPH - HiGraph® Know-how protection User program protection/password protection Block encryption programming / cycle time monitoring / header lower limit adjustable cycle monitoring time / preset	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8 see instruction list see instruction list Yes Yes Yes Yes; Optional Yes; Optional Yes; Optional Yes; Optional Yes; Optional Yes; Optional Yes; Optional Yes; Optional
Configuration rules Configuration software STEP 7 Lite Configuration / programming / header Command set Nesting levels System functions (SFC) System function blocks (SFB) Programming language	 max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list see instruction list see instruction list Yes Yes Yes Yes; Optional Yes; With S7 block Privacy 1 ms 6 000 ms Yes Yes 150 ms
Configuration rules Configuration software STEP 7 Lite Configuration / programming / header Command set Nesting levels System functions (SFC) System function blocks (SFB) Programming languageLADFBDSTLSCLCFCGRAPHHiGraph® Know-how protection User program protection/password protection Block encryption programming / cycle time monitoring / header lower limit upper limit adjustable cycle monitoring time / preset Dimensions Width	 max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list ges instruction list see instruction list Yes Yes Yes Yes; Optional Yes; Optional Yes; Optional Yes; Optional Yes; Optional Yes; With S7 block Privacy 1 ms 6 000 ms Yes Yes 150 ms 60 mm; DP master module: 35 mm
Configuration rules Configuration software STEP 7 Lite configuration / programming / header Command set Nesting levels System functions (SFC) System function blocks (SFB) Programming languageLADFBDSTLSCLCFCGRAPHHiGraph® Know-how protection User program protection/password protection Block encryption programming / cycle time monitoring / headerIow limit	 max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list see instruction list see instruction list Yes Yes Yes Yes; Optional Yes; With S7 block Privacy 1 ms 6 000 ms Yes Yes 150 ms
Configuration rules Configuration software STEP 7 Lite configuration / programming / header Command set Nesting levels System functions (SFC) System function blocks (SFB) Programming languageLADFBDSTLSCLCFCGRAPHHiGraph® Know-how protection User program protection/password protection Block encryption programming / cycle time monitoring / header I ower limit upper limit adjustable cycle monitoring time / preset Dimensions Width	max. 10 Å per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface) No see instruction list 8 see instruction list see instruction list Yes Yes Yes Yes; Optional Yes; Optional Yes; Optional Yes; Optional Yes; Optional Yes; With S7 block Privacy I ms 6 000 ms Yes 150 ms

Weight, approx.

last modified:

200 g; DP master module: Approx. 100 g

4/1/2022 🖸