



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

### Ex COMPONENT CERTIFICATE

Certificate No.:	IECEX ULD 14.0005U	Issue No: 5	<b>Certificate history:</b> Issue No. 5 (2019-04-12) Issue No. 4 (2018-12-17) Issue No. 3 (2017-07-12) Issue No. 2 (2016-11-22) Issue No. 1 (2015-08-11) Issue No. 0 (2014-10-16)
Status:	<b>Current</b>	Page 1 of 5	
Date of Issue:	<b>2019-04-12</b>		
Applicant:	<b>Weidmüller Interface GmbH &amp; Co. KG</b> Klingenbergstrasse 16 32758 Detmold <b>Germany</b>		
Ex Component:	<b>Feed through and protective conductor terminals with accessories - WDU*, WPE* and accessories ZQV*, WQV*, WAP*, WEW*, WTW*, LS 2.8</b>		

This component is NOT intended to be used alone and requires additional consideration when incorporated into other equipment or systems for use in explosive atmospheres (refer to IEC 60079-0).

Type of Protection: **Increased Safety "eb"**

Marking:  
Ex eb IIC Gb

Approved for issue on behalf of the IECEx  
Certification Body:

Susan K. Lee

Position:

Staff Engineer

Signature:  
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

**UL International DEMKO A/S**  
Borupvang 5A,  
DK-2750 Ballerup  
Denmark





# IECEX Certificate of Conformity

Certificate No: IECEX ULD 14.0005U Issue No: 5

Date of Issue: **2019-04-12** Page 2 of 5

Manufacturer: **Weidmüller Interface GmbH & Co. KG**  
Klingenbergstrasse 16  
32758 Detmold  
**Germany**

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex Component covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

## STANDARDS:

The Ex Component and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2017** Explosive atmospheres - Part 0: Equipment - General requirements  
Edition:7.0

**IEC 60079-7 : 2017** Explosive atmospheres - Part 7: Equipment protection by increased safety "e"  
Edition:5.1

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

## TEST & ASSESSMENT REPORTS:

*A sample(s) of the Ex Component listed has successfully met the examination and test requirements as recorded in*

Test Report:

[DK/ULD/ExTR14.0004/05](#)

Quality Assessment Report:

[NL/DEK/QAR12.0052/06](#)



# IECEX Certificate of Conformity

Certificate No: IECEx ULD 14.0005U

Issue No: 5

Date of Issue: 2019-04-12

Page 3 of 5

## Schedule

**Ex Component(s) covered by this certificate is described below:**

Feed through terminal blocks type WDU and protective conductor terminal blocks type WPE are for the connection of copper conductors in enclosures. The type of protection is increased safety, "e", insulating parts made of Wellamid, with optional accessories, type WQV screw in cross-connectors, type ZQV plug-in cross-connectors, type LS2.8 shield bus, type WEW end brackets, type WTW partitions, type WAP end plates for fixing on mounting rails.

**Please see Annex for additional information.**

Please

### SCHEDULE OF LIMITATIONS:

- The feed through and protective conductor terminal blocks are suitable for use in enclosures in atmospheres with flammable gases and combustible dust. For flammable gases these enclosures must satisfy the requirements according to IEC 60079-0 and IEC 60079-7. For combustible dust these enclosures must satisfy the requirements according to IEC 60079-31.
- The terminal blocks shall be placed inside a suitable IECEx certified IP54 enclosure for gas atmosphere. For dust atmosphere the terminal blocks shall be mounted inside a suitable IECEx certified 't' enclosure (IEC 60079-31).
- The enclosure shall be constructed to block all sun and UV light from affecting the terminal blocks.
- Under normal operating conditions the temperature rise of the terminal blocks is max 40 K, measured with the max permitted rated current. Due to the above mentioned the terminal blocks may be used in apparatus of temperature classes T6...T1 as long as the terminal block ambient temperature range is not exceeded as shown below. No part of terminal block must exceed 110 °C under any condition.
  - T6 (- 60°C ≤ Tamb ≤ +40 °C)
  - T5 (- 60°C ≤ Tamb ≤ +55 °C)
  - T4 (- 60°C ≤ Tamb ≤ +70 °C)
- When using the types WDU and WPE with other terminal blocks series or sizes or accessories, the requirements for clearance and creepage distances according to table 1 of IEC 60079-7 must be observed. Regarding the use of covers, cross-connectors and end brackets the instructions of the manufacturer must be followed.
- For terminal jumper accessories current ratings and the resistances across the terminals please refer to the table under "types & electrical rating" above. Details on creepage and clearance values and the required torque values are in the respective "Notice to installers".
- The terminal can be used with either one or two wires into either side of the terminal. When two wires are used they must be of the same type, and of equal sizes. No other wire sizes or types than the ones specified in instructions must be used. The terminal blocks must either be mounted next to another block of the same type and size or with an end plate.
- If smaller conductor cross sections than the rated conductor cross sections are used, then the corresponding lower current shall be stated in the Certificate of the complete apparatus.
- Unused terminals shall be tightened.



# IECEX Certificate of Conformity

Certificate No: IECEx ULD 14.0005U

Issue No: 5

Date of Issue: 2019-04-12

Page 4 of 5

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Issue 1: New models of WDU, WPE, ZQV and WQV added: Models WDU 1.5/R3.5, WDU 1.5/ZZ, WDU 2.5/1.5/ZR, WDU 2.5/TC TYP B, WDU 2.5/TC TYP E, WDU 2.5/TC TYP J, WDU 2.5/TC TYP K, WDU 2.5/TC TYP N, WDU 2.5/TC TYP SR, WDU 2.5/TC TYP T, WDU 2.5N, WDU 4 SL, WDU 4 SL/EN, WDU 4/ZR, WDU 4/ZZ, WDU 4N, WDU 6 SL, WDU 6 SL/EN, WDU 10 SL, WDU 10 SL/EN, WDU 70N/35, WDU 70N/95N, WDU 95N/120N, WDU 120/150, WPE 1.5/ZZ, WPE 2.5/1.5/ZR, WPE 2.5N, WPE 4/ZR, WPE 4/ZZ, WPE 4N, WPE 70/95, WPE 70N/35, WPE 95N/120N, WPE 120/150, ZQV 1.5/3.5/2, WQV 70N/2, WQV 95/120/2 and WQV 70/95/2WQV/120/2. Voltage levels for WDU 6 and WDU 10 have been raised to 690V .

Issue 2: Alternate construction to multiple models.

Issue 3: NTI WDU-WPE 2.5 and NTI WDU-WPE 4 were updated.

Issue 4: Updated standards to latest editions, minor corrections to nomenclature.

Issue 5: New drawings of WPE type terminals added, New drawing for clamping yoke of WDU 35 added, revision of NTI's for WDU/WPE2.5 and WDU/WPE4.



# IECEX Certificate of Conformity

Certificate No: IECEx ULD 14.0005U

Issue No: 5

Date of Issue: 2019-04-12

Page 5 of 5

**Additional information:**

**Annex:**

[Annex to IECEx ULD 14.0005U Issue 5.pdf](#)



# IECEx Certificate of Conformity

Certificate No.:

IECEx ULD 14.0005U

Issue No.:5

Page 1 of 4

## TYPE DESIGNATION AND PARAMETERS RELATING TO THE SAFETY

TYPE	New (N) or original (O)	Rated (V)	Rated (A)	Resistance (uΩ)	Strip length	Solid wire size (mm <sup>2</sup> )	Stranded wire size (mm <sup>2</sup> )	Flexible wire size (mm <sup>2</sup> )	2 wires in one terminal (mm <sup>2</sup> )
WDU 1.5/R3.5	N	275	15	430	7	0,14-1,5	0,14-1,5	0,14-1,5	0,5-0,75
WDU 1.5/ZZ	N	550	17,5	740	7	0,14-2,5	0,14-2,5	0,13-1,5	0,5 -1,0
WDU 2.5N	N	440	24	430	10	0,14-4,0	0,14-4,0	0,5-2,5	0,5-1,5
WDU 2.5/1.5/ZR	O	550	20	720	10	See NTI	See NTI	See NTI	See NTI
WDU2.5**	N	690	24	369	10	0,14-4,0	0,14-4,0	0,14-4,0	0,5-1,5
WDU 2.5/TC B	O	55	8	3300	10	0,14-2,5	0,14-2,5	0,14-2,5	0,5-1,5
WDU 2.5/TC E	O	55	8	8650	10	0,14-2,5	0,14-2,5	0,14-2,5	0,5-1,5
WDU 2.5/TC J	O	55	8	5808	10	0,14-2,5	0,14-2,5	0,14-2,5	0,5-1,5
WDU 2.5/TC K	O	55	8	6705	10	0,14-2,5	0,14-2,5	0,14-2,5	0,5-1,5
WDU 2.5/TC N	O	55	8	9104	10	0,14-2,5	0,14-2,5	0,14-2,5	0,5-1,5
WDU 2.5/TC SR	O	55	8	2055	10	0,14-2,5	0,14-2,5	0,14-2,5	0,5-1,5
WDU 2.5/TC T	O	55	8	4611	10	0,14-2,5	0,14-2,5	0,14-2,5	0,5-1,5
WDU 4**	N	690	32	298	10	0,14-6,0	0,14-6,0	0,14-6,0	0,5-2,5
WDU 4 N	O	352	31	270	11	0,13-6,0	0,13-6,0	0,13-4,0	0,5-1,5
WDU 4/ZR	O	690	31	440	10	0,14-6,0	0,14-6,0	0,14-4,0	0,5-1,5
WDU 4/ZZ	O	690	29,5	560	10	0,14-6,0	0,14-6,0	0,14-4,0	0,5-1,5
WDU 4 SL	O	440	32,0	300	13	0,14-6,0	0,14-6,0	0,14-4,0	0,5-1,5
WDU 4 SL/EN	O	690	32,0	300	13	0,14-6,0	0,14-6,0	0,14-4,0	0,5-1,5
WDU 6	O	690	41	180	12	0,14-10,0	0,14-10,0	0,14-10,0	0,5-2,5
WDU 6 SL	O	275	40	360	16	0,14-10,0	0,14-10,0	0,14-6,0	0,5-2,5
WDU 6 SL/EN TS 32	O	440	40	360	16	0,14-10,0	0,14-10,0	0,14-6,0	0,5-2,5
WDU 6 SL/EN TS 35	O	690	40	360	16	0,14-10,0	0,14-10,0	0,14-6,0	0,5-2,5
WDU 10	O	690	57	152	12	1,31-16,0	1,31-16,0	1,31-16,0	0,5-6,0
WDU 10 SL /EN TS 32	O	550	55	280	17	1,5-16,0	1,5-16,0	0,5-10,0	1,5-4,0
WDU 10 SL /EN TS 35	O	690	55	280	17	1,5-16,0	1,5-16,0	0,5-10,0	1,5-4,0
WDU 10 SL	O	352	55	280	17	1,5-16,0	1,5-16,0	0,5-10,0	1,5-4,0
WDU 16	O	690	76	161	16	1,5-16,0	1,5-25,0	1,5-25,0	1,5-4,0
WDU 35	O	690	115	145	18	2,5-16,0	2,5-50,0	2,5-35,0	2,5-16,0
WDU 35N	O	352	110	122	18	2,5-16,0	2,5-50,0	2,5-35,0	2,5-6,0
WDU 50N	O	690	126	151	24	5,26-16,0	5,26-70,0	5,26-50,0	6,0-16,0





# IECEx Certificate of Conformity

Certificate No.:

IECEx ULD 14.0005U

Issue No.:5

Page 3 of 4

TYPE	New (N) or original (O)	Rated (V)	Rated (A)	Resistance ( $\mu\Omega$ )	Strip length	Solid wire size ( $\text{mm}^2$ )	Stranded wire size ( $\text{mm}^2$ )	Flexible wire size ( $\text{mm}^2$ )	2 wires in one terminal ( $\text{mm}^2$ )
ZQV 1.5N/R3.5	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
ZQV 2.5N	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
ZQV 4N	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 2.5	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 4	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 6	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 10	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 16	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 35	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 35N	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 50N	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 70/95	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 70N	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 95/120	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A
WQV 120	O	See NTI	See NTI	N/A	N/A	N/A	N/A	N/A	N/A

\*\*Two alternate constructions under one Cat. No.





# IECEx Certificate of Conformity

Certificate No.: IECEx ULD 14.0005U

Issue No.:5

Page 4 of 4

## MARKING

This is an example of WDU 4/ZR. For the other types see the respective drawings.



## ROUTINE EXAMINATIONS AND TESTS

According to IEC 60079-7 clause 7.1 in combination with clause 6.1 a dielectric strength test has to be carried out. The routine tests may be performed on a statistical basis according to ISO 2859-1 with an acceptance quality limit (AQL) of 0,04. Routine test is to be carried out according to Weidmüller procedure "High voltage test" Document -NR: A\_10\_54.