

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product	Terminal blocks for copper conductors
Name and address of the applicant	Weidmüller Interface GmbH & Co. KG Klingenbergstrasse 16, 32758 Detmold Germany
Name and address of the manufacturer	Weidmüller Interface GmbH & Co. KG Klingenbergstrasse 16, 32758 Detmold Germany
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Weidmüller Interface GmbH & Co. KG Klingenbergstrasse 16, 32758 Detmold Germany
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	800/1000 V, 8 kV, 24 - 125 A, 2,5 - 35 mm ²
Trademark (if any)	Weidmüller
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	SAK 2,5, SAK 2,5/35, SAK 4, SAK 4/35, SAK 6, SAK 6/35, SAK 10, SAK 10/35, SAK 16, SAK 16/35, SAK 35, SAK 35/35, SAK 35/35/IK
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 -
A sample of the product was tested and found to be in conformity with	IEC 60947-7-1:2009
As shown in the Test Report Ref. No. which forms part of this Certificate	2228552.50 / 2228552.51 / 2228552.52 / 2228552.53 / 2228552.54 / 2228552.55

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

