



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2014010304702907

NAME AND ADDRESS OF THE APPLICANT

CARLO GAVAZZI AUTOMATION (KUNSHAN) CO., LTD
The South of Kunjia Road, Kunshan Development Zone, Jiangsu Province

NAME AND ADDRESS OF THE MANUFACTURER

CARLO GAVAZZI AUTOMATION (KUNSHAN) CO., LTD
The South of Kunjia Road, Kunshan Development Zone, Jiangsu Province

NAME AND ADDRESS OF THE FACTORY

CARLO GAVAZZI AUTOMATION (KUNSHAN) CO., LTD
No.347, Kunjia Road, Kunshan Development Zone Jiangsu Province

PRODUCT NAME, MODEL AND SPECIFICATION

Solid State Contactor

RM, RAM; Ui:690V; Uimp: 4kV; RM:Ue:AC230V/400V/480V/600V; Ith= Ie: 5A,15A,20A,30A; RAM: Ue:AC230V/600V; Ie: 5A,15A,17A,20A,30A; Ue:AC690V; Ie: 17A,20A,30A; Ith: 5A,15A,17A,20A,30A; Utilization Category: AC-53a; IP20; Poles:1P; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Apr.02,2019

Valid until: Apr.02,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Jun.25,2014

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录:

第 1 页 共 4 页

证书编号: 2014010304702907

纸号: 1753331

型号的解释:

RM1 系列

| | | | | | | | |
|---|----|-----|----|---|----|-----|-------|
| R | M | 1 | □ | □ | □ | □ | XXXXX |
| I | II | III | IV | V | VI | VII | X |

I - Designated Basic Series: 指定的基本系列

R - Solid State Contactor: 固态接触器

II - Construction Type: 结构形式

M - Modular Build 模块化构造

III - Number of phase: 相数

1 - Single phase 单相

IV - Switching type: 触发类型

A - Zero Cross Switching 过零触发

B - Instant On Switching 随机触发

V - Voltage Rating: 额定电压

23 - 230 V.

40 - 400 V.

48 - 480 V.

60 - 600 V

注: 此附录与证书同时使用时有效。



主任:



中国质量认证中心



中国国家强制性产品认证证书

附录:

第 2 页 共 4 页

证书编号: 2014010304702907

纸号: 1753331

VI - Control Voltage: 控制电压

D - 3 to 32 V dc

A - 20 to 280 V ac or 22 to 48 V dc

M - 4.25 to 27 V ac or 4.25 to 36 V dc

A1 - 110Vac

A2 - 230Vac

A4 - 400Vac

VII - Current specification: 电流说明

25 - 5 A

50 - 15 A

75 - 20 A

100 - 30 A

X - Suffix for Specials: 特殊的后缀

Blank - Standard Function 空白 - 标准功能

XXXX - Special Function - 特殊功能

注: 此附录与证书同时使用时有效。



主任:



中国质量认证中心



中国国家强制性产品认证证书

附录:

第 3 页 共 4 页

证书编号: 2014010304702907

纸号: 1753331

RAM1 系列

| | | | | | | | |
|---|----|-----|--------------------------|--------------------------|--------------------------|--------------------------|-------|
| R | AM | 1 | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | XXXXX |
| I | II | III | IV | V | VI | VII | X |

I - Designated Basic Series: 指定的基本系列

R - Solid State Contactor: 固态接触器

II - Construction Type: 结构形式

AM - Modular Build 模块化构造

III - Number of phase: 相数

1 - Single phase 单相

IV - Switching type: 触发类型

A - Zero Cross Switching 过零触发

B - Instant On Switching 随机触发

V - Voltage Rating: 电压等级

23 - 230 V

60 - 600 V

注: 此附录与证书同时使用时有效。



主任:



中国质量认证中心



中国国家强制性产品认证证书

附录:

第 4 页 共 4 页

证书编号: 2014010304702907

纸号: 1753331

69 - 690 V

VI - Control Voltage: 控制电压
D - 3 to 32 Vdc (for 230Vac and 400Vac version)
D - 4 to 32 Vdc (for 480/690Vac version)
A - 20 to 280 V ac or 22 - 48 V dc

VII - Current specification: 电流说明
25 - 5 A
50 - 15 A
75 - 17 A
100 - 20 A
125 - 30 A

X - Suffix for Specials 特殊的后缀
Blank - Standard Function 空白 - 标准功能
XXXX - Special Function--特殊功能

注: 此附录与证书同时使用时有效。



主任: 王光博



中国质量认证中心